



**Hampton Roads Sanitation District
Industrial Wastewater Discharge Permit No. 0496**

In accordance with all terms and conditions of the Hampton Roads Sanitation District Industrial Wastewater Discharge Regulations, and in accordance with any applicable provision of Federal or State law or regulation;

Permission is Hereby Granted to: **U. S. Navy, Joint Expeditionary Base, Fort Story, Virginia Beach, Virginia**

Classified by NAICS No. **92811 – Non-Significant Industrial User**

For the contribution of **Industrial Wastes (Military Training Facility)**

into the Hampton Roads Sanitation District at **Atlantic Avenue and 60th Street, Virginia Beach, Virginia**

This Permit is based on information provided in the Permit application which together with the following conditions and requirements is considered a part of this Permit. This Permit is not transferable.

Effective **1st day of October 2009**

To Expire **30th day of September 2014**


General Manager
(By Direction)



**Hampton Roads Sanitation District
Industrial Wastewater Discharge Permit No. 0496**

EFFLUENT DISCHARGE LIMITATIONS

The following referenced parameters are known to exist in the Permittee's discharge through information provided in the Permit application. The limitations set forth below shall be met at all times. In addition, all other effluent limitations and general discharge prohibitions set forth in the Hampton Roads Sanitation District's Industrial Wastewater Discharge Regulations (7/1/99 Ed.) and all applicable Federal and State limitations shall be met.

Sampling Point Name: TOT		
Parameter (reported in mg/L unless otherwise indicated)	Calendar Month Average ¹	Calendar Day Maximum ²
pH (s.u.)	≥5.0	≥5.0
Flow (GPD) ³	225,000	310,000

¹ Average of any number of daily values obtained during a calendar month.

² Maximum for any sample obtained during any calendar day.

³ The flow quantities listed are not enforced as Permit limitations.



**Hampton Roads Sanitation District
Industrial Wastewater Discharge Permit No. 0496**

MONITORING REQUIREMENTS

The following sample(s) shall be collected as specified:

Sampling Point	Quantity	Type	Frequency	Parameter(s)
TOT Manhole near Pump Station #651	1	Grab	Semi-Annually ¹	pH

¹ First sample collected between **January** and **June** and the second sample collected between **July** and **December** of each calendar year in varying months.

Results of *all* analyses for samples collected from the *permitted* sampling point(s) in a calendar month must be received in this office by the tenth (10th) day of the following month.

Transmitting data by facsimile is an acceptable method for meeting this deadline. However, all data must be received in this office within thirty (30) days following this date accompanied by an appropriately executed certification statement.

All analyses shall be performed in accordance with Section 402 of the HRSD Industrial Wastewater Discharge Regulations.



**Hampton Roads Sanitation District
Industrial Wastewater Discharge Permit No. 0496**

METERING REQUIREMENTS

Metering shall be as follows:

Quantity	Type		Purpose
1	Effluent	Billing	

The effluent meter shall be certified as accurate to manufacturer's specifications annually and a copy of the certification shall be received in this office no later than December 31st of each year accompanied by an appropriately executed certification statement.



**Hampton Roads Sanitation District
Industrial Wastewater Discharge Permit No. 0496**

SPECIAL CONDITIONS

All pretreatment devices (oil/water separators and grease traps) shall be maintained as needed. All residual material removed from the oil/water separators shall not be discharged directly or indirectly into the HRSD system.

Permit violations must be reported to the HRSD Pretreatment & Pollution Prevention Division in accordance with Section 302 of the HRSD Industrial Wastewater Discharge Regulations.

The Permittee is responsible for resampling and analysis of any violated parameter based on self-monitoring within thirty (30) days of becoming aware of the violation.

A log shall be maintained for all ROWPU batch discharges. The log shall include the following information:

- (1) Date/time of grab.
- (2) Date/time of pH analysis.
- (3) Initials of sampling individual.
- (4) Initials of individual obtaining pH.
- (5) Method of analysis.
- (6) Date of discharge.

The pH analysis of all ROWPU batches shall be ≥ 5.0 s.u. prior to discharge. The ROWPU log shall be available for inspection by HRSD personnel at all times.

There shall be no visible free oil present at any time in the facility's permitted sampling point.

The Permittee must notify the HRSD Pretreatment & Pollution Prevention Division, in writing, no less than two (2) weeks prior to any major sanitary sewer line cleaning in order to determine appropriate wastewater treatment, disposal, or monitoring requirements.

In accordance with Section 206 of the HRSD Industrial Wastewater Discharge Regulations, a permit renewal application must be received in this office at least 180 days prior to the expiration date of the existing Permit.