

N60200.AR.003827  
NAS CECIL FIELD, FL  
5090.3a

"LETTER REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION  
REVIEW OF FIRST QUARTER FIRST YEAR GROUNDWATER MONITORING REPORT FOR  
BUILDING 81 TANKS 81 A, B AND C NAS CECIL FIELD FL"

2/5/2004

FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



# Department of Environmental Protection


JEU BUSH  
Governor

Twin Towers Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

David B. Struhs  
Secretary

February 5, 2004

Commanding Officer  
Attn: Mr. Gabe Magwood  
Code ES24 (UST RPM)  
Southern Division  
Naval Facilities Engineering Command  
P.O. Box 190010  
North Charleston, South Carolina 29419-9010



RE: Groundwater Monitoring Report, 1<sup>st</sup> Quarter, 1<sup>st</sup> Year (January 2003), Building 81, Tanks 81 A, B and C, Naval Air Station Cecil Field, Jacksonville, Florida


Dear Mr. Magwood:

I have completed my review of the Groundwater Monitoring Report, 1<sup>st</sup> Quarter, 1<sup>st</sup> Year (January 2003), Building 81, Tanks 81 A, B and C, Naval Air Station Cecil Field, dated November 17, 2003 (received November 18, 2003), prepared and submitted by Tetra Tech NUS, Inc. Based upon groundwater contaminant concentrations having been detected above the Department's groundwater cleanup target levels in the vertical perimeter or point of compliance well (CEF-81-01I), I concur with Tetra Tech's recommendation to discontinue groundwater monitoring and that supplemental site assessment be conducted to delineate the vertical extent of groundwater contamination.

If I can be of any further assistance with this matter, please contact me at (850) 245-8997.

Sincerely,

*David P. Grabka*  
David P. Grabka, P.G.  
Remedial Project Manager  
5-February 2004  
date



cc: Mike Fitzsimmons, FDEP Northeast District  
Debbie Vaughn-Wright, USEPA Region 4  
Paul Calligan, Tetra Tech NUS, Tampa

JJC *JJC* ESN *ESN*

"Protect, Conserve and Manage Florida's Environment and Natural Resources"