


N60200.AR.008949  
NAS CECIL FIELD  
5090.3a

LETTER AND CONCURRENCE FROM FLORIDA DEPARTMENT OF ENVIRONMENTAL  
PROTECTION REGARDING SITE MANAGEMENT PLAN REVISION 1998 WITH  
ATTACHMENT NAS CECIL FIELD FL  
3/30/1998  
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



# Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

March 30, 1998

CERTIFIED MAIL  
RETURN RECEIPT REQUESTED

Commanding Officer  
Mr. Mark Davidson, Code 1879  
SOUTHNAVFACENGCOM  
Post Office Box 190010  
North Charleston, SC 29419-9010

RE: 1998 Site Management Plan Revisions  
Naval Air Station Cecil Field, Florida.

Dear Mr. Davidson:

I have completed the review of the 1998 Site Management Plan Revisions dated February 1998 (received February 10, 1998) submitted for the above referenced facility. FDEP concurs on the proposed schedule deadlines and work priorities.

Per the Federal Facilities Agreement, dated 23 October 1990, any changes or extensions must be submitted in writing and approved by USEPA and FDEP.

If you have any concerns regarding this letter, please contact me at (904) 921-9991.

Sincerely,

Michael J. Deliz, P.G.  
Remedial Project Manager

CC: Tony Ettore, FDEP OGC/Natural Resource Trustee File  
Satish Kastury, FDEP  
Debbie Vaughn-Wright, USEPA - Atlanta  
Lewis Shields, City of Jacksonville  
David Porter, SOUTHNAVFACENGCOM  
Eric Blomberg, ABB-ES - Tallahassee

TJB B JCC ME ESN ESN

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

Mr. Bryan Kizer  
Page two of 6

If concentrations of chemicals of concern in any of the designated wells increase above the action levels listed below, the well or wells must be resampled no later than 30 days after the initial positive results are known. If the results of the resampling confirm the initial sampling results, then a proposal must be submitted, as described in Rule 62-770.690(7)(f), F.A.C.

Contaminated well:

MW-CEF-CS1A: 100 µg/l Benzene; 300 µg/l Ethylbenzene; 400 µg/l Toluene; and 200 µg/l Naphthalene.

Perimeter wells:

MW-CEF-CS3 and MW-CEF-CS7: 1 µg/l Benzene; 30 µg/l Ethylbenzene; 40 µg/l Toluene; 20 µg/l Naphthalene.

The approved Remedial Action by Natural Attenuation monitoring period is 5 years. "Milestone" objectives should be established if monitoring is projected to take greater than one year. The following are the "milestone" objectives that will be used for annual evaluation of remediation progress by natural attenuation. An explanation of the progress relative to these milestone objectives, and the need for corrective action (if applicable), should be provided in the annual evaluation:

<u>Benzene</u>	<u>MW-CEF- CS1A</u>
End of year 1	12
End of year 2	10
End of year 3	8
End of year 4	4
End of year 5	ND

<u>Ethylbenzene</u>	
End of year 1	70
End of year 2	50
End of year 3	40
End of year 4	30
End of year 5	25

<u>Toluene</u>	
End of year 1	110
End of year 2	100
End of year 3	80

Mr. Bryan Kizer  
Page three of 6

End of year 4	50
End of year 5	35

Naphthalene

End of year 1	110
End of year 2	90
End of year 3	60
End of year 4	30
End of year 5	15

If the applicable No Further Action criteria in Rule 62-770.680, F.A.C., are achieved at the end of the monitoring period, a Site Rehabilitation Completion Report, summarizing the monitoring program and containing documentation supporting the opinion that the cleanup objectives have been achieved, should be submitted as required in Rule 62-770.690(8), F.A.C. If the applicable No Further Action criteria in Rule 62-770.680, F.A.C., are not achieved following one year of monitoring, then a report summarizing the monitoring program should be submitted, including a proposal as described in Rule 62-770.690(7)(g).

Persons affected by this Order have the following options:

If you choose to accept the above decision by the Department you do not have to do anything. This Order is final and effective as of the date on the top of the first page of this Order.

If you disagree with the decision, you may do one of the following:

1. File a petition for administrative hearing with the Office of the General Counsel of the Department within 21 days after receipt of this Order;

OR

2. File a request for an extension of time to file a petition for hearing with the Office of the General Counsel of the Department within 21 days after receipt of this Order. Such a request should be made if you wish to meet with the Department in an attempt to informally resolve any disputes without first filing a petition for hearing.

Mr. Bryan Kizer  
Page four of 6

Please be advised that mediation of this decision, pursuant to Section 120.573, Florida Statutes (F.S.), is not available.

#### How to Request an Extension of Time to File a Petition for Hearing

A request for an extension of time to file a petition for hearing must be filed (received) in the Office of the General Counsel of the Department at 3900 Commonwealth Boulevard, MS 35, Tallahassee, Florida 32399-3000, within 21 days after receipt of this Order. Pursuant to Rule 28-106.111(3), F.A.C., a request for extension of time shall contain a certificate that the moving party has consulted with all other parties, if any, concerning the extension and that the Department and any other parties agree to said extension. Petitioner, if different from Commanding Officer, Naval Air Station Cecil Field, shall mail a copy of the petition to from Commanding Officer, Naval Air Station Cecil Field at the time of filing. Timely filing a request for an extension of time tolls the time period within which a petition for administrative hearing must be filed until the request is acted upon.

#### How to File a Petition for Administrative Hearing

A person whose substantial interests are affected by this Order may petition for administrative hearing in accordance with Sections 120.569 and 120.57, F.S. The petition must contain the information set forth below and must be filed (received) in the Office of the General Counsel of the Department at 3900 Commonwealth Boulevard, MS 35, Tallahassee, Florida 32399-3000, within 21 days after receipt of this Order. Petitioner, if different from from Commanding Officer, Naval Air Station Cecil Field, shall mail a copy of the petition to from Commanding Officer, Naval Air Station Cecil Field at the time of filing. Failure to file a petition within this time period shall waive the right of anyone who may request an administrative hearing under Sections 120.569 and 120.57, F.S.

Pursuant to Rules 62-103.155 and 28-106.201, F.A.C., a petition for administrative hearing shall contain the following information:

- a) The name, address, and telephone number of each petitioner, the name, address, and telephone number of the petitioner's representative, if any, the site owner's name and address, if different from the petitioner, the

- FDEP facility number, and the name and address of the facility;
- b) A statement of how and when each petitioner received notice of the Department's action or proposed action;
  - c) A statement of how each petitioner's substantial interests are affected by the Department's action or proposed action;
  - d) A statement of the material facts disputed by the petitioner, if any;
  - e) A statement of facts which petitioner contends warrant reversal or modification of the Department's action or proposed action;
  - f) A statement of which rules or statutes petitioner contends requires reversal or modification of the Department's action or proposed action; and
  - g) A statement of the relief petitioner seeks, stating precisely what petitioner wants the Department to do regarding the Department's action or proposed action.

This Order is final and effective as of the date on the top of the first page of this Order. Timely filing a petition for administrative hearing postpones the date this Order takes effect until the Department issues either a Final Order pursuant to an administrative hearing or an Order Responding to Supplemental Information provided pursuant to meetings with the Department.

#### Judicial Review

Any party to this Order has the right to seek judicial review of this Order pursuant to Section 120.68, F.S., by filing a Notice of Appeal pursuant to Rule 9.110, Florida Rules of Appellate Procedure, with the Department clerk in the Office of the General Counsel, 3900 Commonwealth Boulevard, MS 35, Tallahassee, Florida 32399-3000. Simultaneously with filing a Notice of Appeal with the Department, petitioner must file a copy of the Notice of Appeal with the applicable filing fees, with the appropriate District Court of Appeal. The Notice of Appeal must be received by the Department clerk within 30 days from the date this Order was signed by the Department clerk (see below).

#### Questions

Should you have any questions regarding the legal processes, please contact the Office of the General Counsel at (850) 488-9730. Any questions you may have on the technical aspects of this Order should be directed to Michael J. Deliz,

Mr. Bryan Kizer  
Page six of 6

P.G. at (850) 921-9991. Contact with any of the above does not constitute a petition for administrative hearing.


Sincerely,




John M. Ruddell, Director  
Division of Waste Management

JMR/mjd

FILING AND ACKNOWLEDGMENT  
FILED, on this date, pursuant to  
§120.52 Florida Statutes, with the  
designated Department Clerk, receipt  
of which is hereby acknowledged.

  
Clerk  
(or Deputy Clerk)

  
Date

c: Deborah Metrin, FDEP Central District  
David Kruzicki, NAS Cecil Field

**NAS CECIL FIELD  
FREE PRODUCT MEASUREMENTS  
DAY TANKS I & II  
FEBRUARY 17, 1998**

**DAY TANK I**

<u>Well/Piezometer #</u>	<u>FID</u>	<u>D.T.W</u>	<u>D.T.P</u>	<u>Product Thickness</u>
CEF-293-7	>5,000	7.23	7.22	0.01'
CEF-293-9	>5,000	6.85	6.70	0.15'
CEF-293-PZ3	>5,000	8.29	7.70	0.59'
CEF-293-PZ4	>5,000	8.12	---	----
CEF-293-PZ5	>5,000	7.15	---	----
CEF-293-PZ6	>5,000	7.91	7.88	0.03'

**DAY TANK II**

CEF-043-25	1,000	4.15	3.89	0.26'
CEF-043-40	150	3.22	----	----
CEF-043-41	>5,000	5.06	3.83	1.23'
CEF-043-PZ3	2,200	7.68	5.58	2.10'
CEF-043-PZ4	>5,000	5.79	5.70	0.09'
CEF-043-PZ12	1,200	8.46	7.18	1.28'

\* NOTE: CEF-043-PZ2 WAS DESTROYED DURING TANK EXCAVATION.