

N61165.AR.005040  
CNC CHARLESTON  
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND  
ENVIRONMENTAL CONTROL APPROVAL OF MONITORING WELL CONSTRUCTION AT  
DEFENSE FUEL SUPPLY POINT GROUND WATER SITE #13407 CNC CHARLESTON SC  
01/09/1992  
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

## Monitor Well Approval

Approval is hereby granted to: United States Geological Survey  
Stephenson Center, Suite 129  
720 Gracen Road  
Columbia, SC 29210-7651

RE: Defense Fuel Supply Point  
GWPD Site # 13407  
Berkeley County

for the construction of monitoring wells designated MWGS-31A and MWGS-31B in accordance with the construction plans and specifications submitted on October 7, 1991.

This well will be constructed to the approximate depth of 25 feet below the surface and screened in the surficial aquifer for the purpose of monitoring ground-water quality.

Conditions: That the latitude and longitude and actual construction details for each well be submitted within 30 days after installation. That the District Hydrologist, Christine Sanford Coker, Trident EQC District Office, (803) 554-5533, be notified at least 72 hours prior to installation.

This approval is pursuant to the provisions of Section 44-55-40 and Section 48-1 of the 1976 South Carolina Code of Laws and the Department of Health and Environmental Control Regulations R.61-71.

Please reference the GWPD Site Number on all correspondence.

Date of Issue January 9, 1992.

  
\_\_\_\_\_  
David G. Baize, Manager  
Assessment and Development Section  
Ground-Water Protection Division  
Bureau of Drinking Water Protection

RD/sa

0109923069/RD

cc: Christine Sanford Coker, Trident EQC District  
Marvin Murray, Enforcement  
Wayne Fanning, Trident EQC District