

N61165.AR.005386  
CNC CHARLESTON  
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND  
ENVIRONMENTAL CONTROL REVIEW OF CLOSURE REPORT RECEIVED 21 DECEMBER  
1995 FOR BUILDING 903 CNC CHARLESTON SC  
02/16/1996  
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



Department of Health and Environmental Control  
2600 Bull Street, Columbia, SC 29201

Commissioner: Douglas E. Bryant

Board: John H. Burriss, Chairman  
Sandra J. Molander, Secretary

Richard E. Jabbour, DDS  
William M. Hull, Jr., MD  
Roger Leaks, Jr.

Promoting Health, Protecting the Environment

February 16, 1996

M.L. Hendrick  
Deputy Public Works Officer  
Department of the Navy  
Charleston Naval Weapons Station  
2316 Red Bank Road, Ste. 100  
Goose Creek, South Carolina 29445-8601

RE: Charleston Naval Weapons Station,  
Building 903  
Site ID #A-10-AA-17340  
Closure Report received December 21, 1995  
Charleston County

Dear Mr. Hendrick:

The Ground-Water Protection Division (GWPD) of the South Carolina Department of Health and Environmental Control (SCDHEC) has reviewed the referenced closure report. This report documents groundwater contamination at the location of the former heating oil underground storage tank. The GWPD concurs with the conclusion outlined in the report that additional assessment is necessary to define the extent and severity of the contamination. Therefore, the GWPD requests that a assessment plan to complete assess the site be submitted for approval on or before April 30, 1996.

On all future correspondence concerning this site, please reference the appropriate GWPD number. If you have any questions, please call me at (803) 734-5328.

Sincerely,

Timothy A. Mettlen, Hydrogeologist  
Assessment and Development Section  
Ground-Water Protection Division  
Bureau of Drinking Water Protection

tam\cnws903.ap.

cc: Christine Sanford-Coker, Trident District EQC