

N61165.AR.005394
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF CORRECTIVE ACTION PLAN (CAP) RECEIVED
29 JANUARY 2003 FOR ZONE H ABOVE GROUND STORAGE TANK NS-14 (AST NS-14)
AREA OF CONCERN 659 (AOC 659) CNC CHARLESTON SC
01/29/2003
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



29 January 2003

2600 Bull Street
Columbia, SC 29201-1708

COMMISSIONER:
C. Earl Hunter

BOARD:
Bradford W. Wyche
Chairman

Mark B. Kent
Vice Chairman

Howard L. Brilliant, MD
Secretary

Carl L. Brazell

Louisiana W. Wright

L. Michael Blackmon

Larry R. Chewning, Jr., DMD

Commander
NAVFACENGCOM Southern Division
Attn: Code ES24 (Gabriel Magwood)
P.O. Box 190010
North Charleston, SC 29419-9010

RE: AST NS 14 (AOC 659 – Zone H)
Site ID # 01311
Corrective Action Plan received 29 January 2003
Charleston County

Dear Mr. Magwood:

The Department has completed technical review of the referenced document. As submitted, the plan provides for AFVR events to eliminate free product at the subject site. The proposed remedial program appears reasonable for the known contaminants and the facility may proceed, as appropriate. Please note that, prior to implementation of any AFVR events, the Navy must submit emissions modeling information to the Bureau of Air Quality (BAQ). Once submitted, the BAQ will determine if a permit is required to proceed. Any amendments to the proposed CAP should be submitted in writing to the Department and receive approval prior to implementation.

Per the submitted CAP, the Navy plans to utilize onsite monitoring wells as AFVR points. Please note that the Department will require the Navy to demonstrate via confirmation wells that all free product has been removed from the subject site.

Please submit a remediation monitoring report no later than 30 April 2003. Should you have any questions please contact me at 803-898-3553 (office phone), 803-898-3795 (fax) or by e-mail bishopma@dhec.sc.gov.

Sincerely,

Michael A. Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC
Mary Peyton Davis - BAQC
Jerry Stamps - BLWM
Brian Crawford, 1849 Ave F, N Charleston, SC 29405
Technical File