

N61165.AR.005410
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF CORRECTIVE ACTION REPORT RECEIVED 27
DECEMBER 2006 FOR ZONE H SITE 4 BUILDING 640 CNC CHARLESTON SC
01/09/2007
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

BOARD:
Elizabeth M. Hagood
Chairman
Edwin H. Cooper, III
Vice Chairman
Steven G. Kisner
Secretary



C. Earl Hunter, Commissioner

Promoting and protecting the health of the public and the environment

BOARD:
Henry C. Scott
Paul C. Aughtry, III
Glenn A. McCall
Coleman F. Buckhouse, MD

9 January 2007

Dudley Patrick
BRAC PMO SE
PO Box 190010
North Charleston, SC 29419-9010

RE: CNB - Zone H, Site 4/ Building 640 (Heating Oil UST)
Site Identification # 00955
Corrective Action Report received 27 December 2006
Charleston County

Dear Mr. Patrick:

The Department has completed technical review of the referenced document. Interpretation of the analytical data provided in the referenced report indicates that chemicals of concern remain above established Risk-Based Screening Levels and MCLs.

The Department concurs with the conclusions as presented in the report and passive free product recovery and routine groundwater monitoring and reporting should continue. Given the limited aerial extent of the contamination and relatively shallow groundwater, CNB may wish to consider more proactive measures to deal with the contamination at Building 640.

Please submit the next monitoring report no later than 31 August 2007. Should you have any questions, please contact me at 803-898-3553 (office phone), 803-898-3795 (fax) or bishopma@dhec.state.sc.us.

Sincerely,

Michael Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

cc: Region 7 District EQC
Jerry Stamps-BLWM
Andrew O'Connor, CH2MHILL, 1330 Kilo Street, N. Charleston, SC 29405
Technical File