

N61165.AR.005415
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF CORRECTIVE ACTION REPORT RECEIVED 1
DECEMBER 2004 FOR ZONE H SITE 44 ABOVE GROUND STORAGE TANK 601 (AST 601)
CNC CHARLESTON SC
12/01/2004
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

BOARD:
Elizabeth M. Hagood
Chairman
Mark B. Kent
Vice Chairman
Howard L. Brilliant, MD
Secretary



BOARD:
Carl L. Brazell
Louisiana W. Wright
L. Michael Blackmon
Coleman F. Buckhouse, MD

C. Earl Hunter, Commissioner

Promoting and protecting the health of the public and the environment.

1 December 2004

Commander
NAVFACENGCOM Southern Division
Attn: Code ES24 (Gabriel Magwood)
P.O. Box 190010
North Charleston, SC 29419-9010

RE: CNB - Zone H, Site 44/ AST 601
Site Identification # 01537
Corrective Action Report received 1 December 2004
Charleston County

Dear Mr. Magwood:

The Department has completed technical review of the referenced document. Interpretation of the analytical data provided in the referenced report indicates that chemicals of concern remain above established Risk-Based Screening Levels and MCLs. The Department concurs with the conclusions as presented in the report and free product recovery and groundwater monitoring and reporting should continue as prescribed in the Corrective Action Plan. The Department requests that, in addition to free product recovery activities, all site monitoring wells be sampled on an annual basis.

Please submit the next Corrective Action Report no later than 30 June 2005. Should you have any questions, please contact me at 803-898-3553 (office phone), 803-898-2893 (fax) or bishopma@dhec.sc.gov.

Sincerely,

Michael Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC
Jerry Stamps-BLWM
Andrew O'Connor, CH2MHILL, 1330 Kilo Street, N. Charleston, SC 29405
Technical File