

N61165.AR.005518
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF REMEDIATION MONITORING REPORT
RECEIVED 14 AUGUST 2006 FOR ZONE I SITE 36 BUILDING NS-26 CNC CHARLESTON
SC
09/18/2006
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

BOARD:
Elizabeth M. Hagood
Chairman
Edwin H. Cooper, III
Vice Chairman
Steven G. Kisner
Secretary



C. Earl Hunter, Commissioner

Promoting and protecting the health of the public and the environment

BOARD:
Henry C. Scott
Paul C. Aughtry, III
Glenn A. McCall
Coleman F. Buckhouse, MD

18 September 2006

Dudley Patrick
BRAC PMO SE
PO Box 190010
N.Charleston, SC 29419-9010

RE: CNB-Site 36, BLDG NS26, Zone I (UST)
Site Identification # 00944
Remediation Monitoring Report received 14 August 2006
Charleston County

Dear Mr. Patrick:

The Department has completed technical review of the referenced document. As submitted, the Remediation Monitoring Report provides a synopsis of corrective action activities performed to remediate hydrocarbon contamination at the referenced facility.

Interpretation of the analytical data provided in the referenced report indicates that free product persists at this site. The Department concurs with the recommendations of your contractor, passive free product removal and semi-annual groundwater sampling activities should continue. Again, given the shallow groundwater at CNB and the relatively limited extent of free product at this site, the Navy should explore the feasibility of a limited soil removal action to expedite remedial activities.

Please submit the next Remediation Monitoring Report no later than 29 December 2006. Should you have any questions please contact me at 803-898-3553 (office phone), 803-898-2893 (fax) or by e-mail bishopma@dhec.sc.gov.

Sincerely,

Michael A. Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

cc: Region 7 District EQC
Jerry Stamps, SCDHEC-BLWM
Andrew O'Connor, CH2MHILL, 1330 Kilo Street, North Charleston, SC 29405
Technical File