

N61165.AR.005596
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF UNDERGROUND STORAGE TANK (UST)
CLOSURE REPORT RECEIVED 27 DECEMBER 1995 FOR BUILDING 1025F CNC
CHARLESTON SC
02/14/1996
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

February 14, 1996

M.L. Hendrick
Deputy Public Works Officer
Department of the Navy
Charleston Naval Weapons Station
2316 Red Bank Road, Ste. 100
Goose Creek, South Carolina 29445-8601

RE: Charleston Naval Weapons Station,
Building 1025F, Tank #2, Family Housing
Site ID #A-10-AA-17077
Closure Report received December 27, 1995
Charleston County

Dear Mr. Hendrick:

The Ground-Water Protection Division (GWPD) of the South Carolina Department of Health and Environmental Control (SCDHEC) has reviewed the referenced closure report. This report had been requested by the GWPD in a correspondence dated October 3, 1995. The GWPD concurs with the conclusions outlined in the report that additional assessment is necessary to define the dissolved and/or free-product plume and that free-product recovery should continue. Therefore, the GWPD requests that a assessment plan to complete assess the site be submitted for approval on or before April 30, 1996.

On all future correspondence concerning this site, please reference the appropriate GWPD number. If you have any questions, please call me at (803) 734-5328.

Sincerely,



Timothy A. Mettlen, Hydrogeologist
Assessment and Development Section
Ground-Water Protection Division
Bureau of Drinking Water Protection

tam\cnws1025.f

cc: Christine Sanford-Coker, Trident District EQC