

N60201.AR.000447
NS MAYPORT
5090.3a

LETTER REGARDING QUARTERLY REPORT NUMBER 1 TO FULFILL THE REPORTING
AND SAMPLING REQUIREMENTS OF THE CONSENT AGREEMENT NS MAYPORT FL
1/8/1999
DEPARTMENT OF THE NAVY



DEPARTMENT OF THE NAVY
NAVY PUBLIC WORKS CENTER JACKSONVILLE
JACKSONVILLE, FLORIDA 32212-0030

5090
Ser 300/0006

JAN 08 1999

Florida Department of Environmental Protection
Northeast District
Attn: Mr. Ernest E. Frey, P.E.
7825 Baymeadows Way
Suite B200
Jacksonville, FL 32256-7590

Dear Mr. Frey:

SUBJECT: QUARTERLY REPORT NO. 1, OGC CONSENT ORDER NO. 97-1873,
NAVAL STATION MAYPORT WWTP - DUVAL COUNTY, FDEP PERMIT
NO. DO16273563.

This status report is submitted to fulfill the Reporting and Sampling requirements contained in paragraph 23 of our Consent Agreement dated November 30, 1998. We started our aggressive program to correct plant deficiencies in November 1997. OMI has made its final treatment plant diagnostic evaluation and has closed out 191 of the 192 deficiencies. The last deficiency, cleaning the primary clarifiers, is discussed below.

Enclosure (1) is the Compliance Program from Paragraph 19 of the Consent Agreement showing scheduled dates for completion and actual completion dates. All items from Paragraph 19 have been completed.

Paragraph 26 of the Consent Order requires the removal of oily waste and sludge from the unused clarifiers/holding tanks by April 1, 1999. The pre-construction meeting for this work is scheduled to occur by January 15, 1998. Water from a holding pond that usually passes through these primary clarifiers will be diverted to a nearby manhole that eventually drains to the oily wastewater collection system. Once the piping has been installed for this diversion, the cleaning of the primary clarifiers should be finished shortly thereafter.


As requested in paragraph 24 of the Consent Order, a copy of the updated Operation and Maintenance Manual is provided with this letter.

5090
Ser 300/0006

Since the effective date of the Consent Order, November 30, 1998, we have not exceeded our FDEP permit effluent limits.

Our point of contact is Mr. Fred Burns at (904) 542-4548, extension 8312.

Sincerely,



R. EL-MOSLIMANY
Lieutenant, CEC, U.S. Navy
Deputy Environmental
Department Head
By Direction of the
Commanding Officer

Enclosure: 1. Compliance Program Table
2. Operation and maintenance Manual

Copy to: (w/o Encl 2)
COMNAVBASE Jacksonville (N4)
NAVSTA Mayport (N4)
FDEP, NE District
Jacksonville Regulatory and
Environmental Services Department
LCJ (Chris Taylor)