

M60050-001111



ORANGE COUNTY WATER DISTRICT
10500 Ellis Avenue
Post Office Box 8300
Fountain Valley, CA 92728-8300
Telecopier: (714) 378-3373

M60050.001111
MCAS EL TORO
SSIC # 5090.3

TELECOPIER TRANSMITTAL

TO: Andy Piszkin/Navy SWDIV

RE: Latest TCE Conc. in Woodbridge North Lake Well

TELECOPIER NO.: 619-532-2469

PLEASE REVIEW AND COMMENT

PER YOUR REQUEST

FOR YOUR INFORMATION

SENT BY: Roy Herndon

DATE: December 1, 1994

TIME: 16:15

1 PAGE(S) TO BE TRANSMITTED PLUS COVER SHEET.

THIS DOCUMENT(S) WILL NOT BE TRANSMITTED BY REGULAR MAIL.

COMMENTS:

Andy, I just thought I would keep passing any interesting data I see to you FYI. Any questions, give me a call.

Roy

IF YOU DO NOT RECEIVE ALL PAGES OR IF THEY ARE NOT LEGIBLE, PLEASE CALL THE DISTRICT IMMEDIATELY AT (714) 378-3200. THANK YOU.

From: Lily Vuong (LV)
 To: YS, MPW, NY, MR
 Date: Friday, November 18, 1994 2:37 pm
 Subject: ACTION LEVEL NOTIFICATION-WATER QUALIT

ORANGE COUNTY WATER DISTRICT
 ORGANIC LABORATORY
 ACTION LEVEL NOTIFICATION

THE FOLLOWING CONSTITUENTS ARE PRESENT IN CONCENTRATIONS THAT ARE ABOVE THE STATE ACTION LEVEL OR ARE PRESENT IN LEVELS THAT REQUIRE IMMEDIATE ATTENTION.

Well ID	Date Sampled	Date Analyzed
WOOD INLK/1_____	__11/2/94_____	11/7/94 & 11/16/94__

Title 22/Drinking Water Well? _____ X
 (Yes) (No)

Resample ? _____ X
 (Yes) (No)

Constituent - Concentration - MCL

Total THM _____	100 ug/L	TCE _____	8.3	5 ug/L
1,2 DCA _____	0.5 ug/L	DCEP _____	0.2	ug/L
1,1 DCE _____	6 ug/L	EDB _____	0.02	ug/L
PCE _____	5 ug/L	Vinyl Chloride _____	0.5	ug/L
1,1,1 TCA _____	200 ug/L	Simazine _____	10	ug/L
_____	_____	_____	_____	_____
_____	_____	_____	_____	_____

* = Denotes duplicate analysis

Chemist's comments: This sample was run on 11/7/94, but the instrument was having problem and the results were not reliable.

The sample was rerun on 11/16/94 to confirm the results.

CC: MB, SF, BMO