



DEPARTMENT OF THE NAVY
BASE REALIGNMENT AND CLOSURE
PROGRAM MANAGEMENT OFFICE WEST
1455 FRAZEE RD, SUITE 900
SAN DIEGO, CA 92108-4310

AR_N00217_000891
HUNTERS POINT
SSIC NO. 5090.3.A

5090
Ser BPMOW.mrk/0227
7 Mar 2006

Mr. Wilfred Francis Albovias
Industrial Power Engineer
Service Planning Department
PG&E
2180 Harrison Street
San Francisco, CA 94110

SUBJECT: NOTIFICATION #101654766 POWER INSTALLATION NEAR BUILDING
810, HUNTERS POINT SHIPYARD, SAN FRANCISCO, CA

Dear Mr. Albovias:

Please find attached, a letter from Innovative Technical Solutions, Inc. (ITSI), our consultant, certifying that the pole installation at Building 810 has been performed according to PG&E specifications for the planned power installation for the ongoing Parcel E Landfill Gas Operations & Maintenance activities.

ITSI is approved to work on the Navy's behalf under Contract N68711-02-D-8213, CTO-013.

Should you have any concerns with this matter, please contact Ms. Melanie Kito at (619) 532-0787.

Sincerely,

A handwritten signature in black ink, appearing to read "Keith Forman", written over a horizontal line.

KEITH FORMAN
BRAC Environmental Coordinator
By direction of the Director

Enclosure: 1. ITSI letter to PG&E for notification of power installation near Building 810

5090
Ser BPMOW.mrk/0227
7 Mar 2006

Copy to:
Mr. Michael Work (SFD 8-3)
U.S. Environmental Protection Agency
Region IX
75 Hawthorne Street
San Francisco, CA 94105-3901

Mr. Jim Ponton
California Regional Water Quality Control Board
San Francisco Bay Region
1515 Clay Street, Suite 1400
Oakland, CA 94612

Mr. Tom Lanphar
Department of Toxic Substances Control
700 Heinz Avenue, Bldg. F, Suite 200
Berkeley, CA 94710

5090
Ser BPMOW.mrk/0227
7 Mar 2006

Blind copy to:
DASN (I&E)
SWDIV EDVR.DS (Admin file)
BPMOW
K. Forman
P. Brooks
M. Kito
Read file
Serial file

Writer: M. Kito, 2-0787
Typist: N. Lilley, 03/13/06

Email/PGE notification letter 030706.doc



**Innovative
Technical
Solutions, Inc.**

March 10, 2006

Mr. Wilfred Francis Albovias
Industrial Power Engineer
Service Planning Department
PG&E
2180 Harrison Street
San Francisco, CA 94110

Subject: Notification #101654766
Power Installation near Building 810, Hunters Point Shipyard

Dear Mr. Albovias:

On behalf of the Navy, ITSI performed an inspection on March 9, 2006, of the new power poles, fused disconnect switch and metering enclosure for the subject project. The installation satisfies the requirements of the 2005 National Electrical Code (NFPA 70) and PG&E Document 025055, "Requirements for Customer-Owned Poles."

Sincerely,
Innovative Technical Solutions, Inc

A handwritten signature in black ink that reads "Richard C. Lennig". The signature is written in a cursive, flowing style.

Richard C. Lennig
Senior Electrical Engineer
CA Registered EE No. E11000, Exp. 6/30/2007

cc: Pat Brooks, BRAC PMO, US Navy
cc: Melanie Kito, BRAC RPM, Us Navy

2730 Shadelands Drive, Suite 100, Walnut Creek, CA 94598