

Sample Number ^[a]	PFOA (ppt)	PFOS (ppt)	PFOA + PFOS (ppt) ^[b]	PFNA (ppt)	PFHxS (ppt)	HFPO-DA (ppt)	PFBS (ppt)	Hazard Index ^[c]
2023 Sampling								
1	ND	ND	NC	ND	ND	ND	ND	NC
2	5.34	8.04	13.38	ND	6.22	ND	4.1	0.6
3	4.94	5.78	10.72	ND	4.28	ND	6.51	0.4
4	3.85	4.55	8.40	ND	3.98	ND	0.735 J	0.4
5	ND	ND	NC	ND	ND	ND	ND	NC
6	0.749 J	0.909 J	1.658	ND	2.38	ND	0.744 J	0.2
7	ND	ND	NC	ND	ND	ND	ND	NC
8	ND	ND	NC	ND	ND	ND	ND	NC
9	ND	2.64	NC	ND	1.8 J	ND	ND	NC
10	ND	2.11	NC	ND	2.02	ND	ND	NC
11	ND	1.32 J	NC	ND	2.13	ND	ND	NC
12	ND	ND	NC	ND	ND	ND	ND	NC
13	ND	ND	NC	ND	ND	ND	ND	NC
14	ND	1.29 J	NC	ND	ND	ND	ND	NC
15	ND	ND	NC	ND	ND	ND	ND	NC
16	ND	ND	NC	ND	ND	ND	ND	NC
17	ND	ND	NC	ND	ND	ND	ND	NC
18	ND	ND	NC	ND	ND	ND	ND	NC
19	ND	ND	NC	ND	ND	ND	ND	NC
2025 Sampling								
20	4.67	7.12	11.79	0.51 J	1.02 J	ND	1.75 J	0.2
21	4.89	6.39	11.28	ND	2.98	ND	0.87 J	0.3

Sample Number ^[a]	PFOA (ppt)	PFOS (ppt)	PFOA + PFOS (ppt) ^[b]	PFNA (ppt)	PFHxS (ppt)	HFPO-DA (ppt)	PFBS (ppt)	Hazard Index ^[c]
2025 Sampling								
22	4.42	7.61	12.03	0.43 J	1.05 J	ND	1.5 J	0.1
23	0.49 J	ND	NC	ND	ND	ND	0.44 J	NC
24	ND	ND	NC	ND	ND	ND	ND	NC
25	ND	ND	NC	ND	ND	ND	ND	NC
26	1.63 J	2.27	3.90	0.33 J	0.42 J	ND	0.69 J	0.1
27	ND	ND	NC	ND	ND	ND	ND	NC
28	2.88	ND	NC	0.41 J	0.59 J	ND	1.76 J	0.1
29	ND	ND	NC	ND	ND	ND	ND	NC
30	0.57 J	ND	NC	ND	ND	ND	0.71 J	NC
31	2.17 J	0.86 J	3.03	ND	0.5 J	ND	0.56 J	0.1
32	1.65 J	3.49	5.14	ND	2.47	ND	0.79 J	0.2
33	7.82	4.06	11.88	ND	4.32	ND	0.91 J	0.4
34	1.16 J	8.91	10.07	ND	2.21 J	ND	1.51 J	0.2
35	ND	ND	NC	ND	ND	ND	ND	NC
36	ND	ND	NC	ND	ND	ND	ND	NC
37	ND	ND	NC	ND	ND	ND	ND	NC
38	ND	ND	NC	ND	ND	ND	ND	NC
39	6.69	7.18	13.87	ND	4.96	ND	1.36 J	0.5
40	ND	ND	NC	ND	ND	ND	ND	NC
41	5.39	6.54	11.93	0.36 J	5.35	ND	4.5	0.6
42	4.35	4.79	9.14	ND	3.39	ND	7.41	0.3
43	3.73	3.96	7.69	ND	3.23	ND	0.77 J	0.3

Sample Number ^[a]	PFOA (ppt)	PFOS (ppt)	PFOA + PFOS (ppt) ^[b]	PFNA (ppt)	PFHxS (ppt)	HFPO-DA (ppt)	PFBS (ppt)	Hazard Index ^[c]
2025 Sampling								
44	0.85 J	1.34 J	2.19	ND	0.47 J	ND	0.59 J	0.05

PFAS shown in this table are those with DoD PFAS Interim Action Levels for Private Drinking Water Wells ("certain PFAS"). Each sample row is shaded to indicate whether or not certain PFAS were detected.

Certain PFAS <u>not</u> detected in sample
Certain PFAS detected in sample

^[a] Sample numbers do not correspond to a specific property, and highest calculated HI along with corresponding PFNA, PFHxS, HFPO-DA, and PFBS results for each drinking water source sampled are shown.

^[b] PFOA+PFOS is only calculated when both are detected. Table displays the highest calculated sum of PFOA and PFOS and corresponding individual PFOA and PFOS concentrations. For any drinking water wells with PFOA and/or PFOS individually or combined above 70 ppt, the Navy can provide bottled water for drinking and cooking until a more enduring solution is implemented.

^[c] Hazard Index is calculated for HFPO-DA, PFBS, PFNA, and PFHxS when two or more of these compounds are detected in the sample. Table displays highest calculated HI along with corresponding PFNA, PFHxS, HFPO-DA, and PFBS results for each drinking water source sampled. Calculated per USEPA recommendations (*Maximum Contaminant Level Goals [MCLGs] for Three Individual Per- and Polyfluoroalkyl Substances [PFAS] and a Mixture of Four PFAS, 2024*) as follows:

$$\text{Hazard Index (unitless)} = \frac{\text{HFPO-DA (ppt)}}{10 \text{ (ppt)}} + \frac{\text{PFBS (ppt)}}{2,000 \text{ (ppt)}} + \frac{\text{PFNA (ppt)}}{10 \text{ (ppt)}} + \frac{\text{PFHxS (ppt)}}{10 \text{ (ppt)}}$$

J = analyte positively identified, but the reported value is approximated.

NC = not calculated

ND = not detected

ppt = parts per trillion