









22.C.05 Metal frame scaffolds.
e. Where uplift may occur, panels shall be locked together vertically by pins or other equivalent suitable means





11.A.01

a. All electrical wiring and equipment shall be a type listed by a nationally recognized testing laboratory for the specific application for which it is to be used







16.G.04 Responsibilities.

a. The responsibilities of the operator shall include, but are not limited to the following requirements:

(4) All persons are clear of the swing radius of the counterweight.







22.B.08 Planking.

j. Planks shall be maintained in good condition. When cracks exceed 1.5 times the width of the board the plank will not be used. Planks with notches deeper than $\frac{1}{3}$ the width of the plank will not be used. Planks with saw kerfs shall not be used.







24.A.01 Safe access shall be provided to work areas and where danger exists of workers falling through floor, roof, or wall openings, or from platforms, runways, ramps, or fixed stairs.

22.B.11 Access.

- a. An access ladder or equivalent safe access shall be provided.

22.B.07 Working levels of work platforms shall be fully planked or decked.





27.A.02 Employees shall not be permitted to work above or in positions exposed to protruding reinforcing steel, fasteners, or other impalement hazards unless provisions have been made to control the hazard





15.A.01 Inspection and use.

- a. Rigging equipment shall be inspected as specified by the manufacturer, by a Competent Person, before use on each shift and as necessary during its use to ensure that it is safe.
- b. Defective rigging shall be removed from service.





15.A.06 Hooks, shackles, rings, pad eyes, and other fittings that show excessive wear or that have been bent, twisted, or otherwise damaged shall be removed from service

* This hook has been welded on