



**OHM Remediation
Services Corp.**

A Subsidiary of OHM Corporation

December 21, 1994

Lt. Steve Challeen
ROICC Jacksonville
1005 Michael Road
Camp Lejeune, NC 28542-2521

RE: LANTDIV RAC Contract N62470-93-D-3032
Delivery Order No. 0015; MCB Camp Lejeune,
Addendum No. 2- Bid Package for
Jet Mixing Equipment
RFQ No. 16032-79090

Dear Lt. Challeen:

Enclosed herewith please find one copy of the Addendum No. 2 package for Jet Mixing Equipment for the Groundwater Treatment Building on Lot 203.

If you should have any questions regarding the enclosed, please do not hesitate to contact us.

Very truly yours,

OHM REMEDIATION SERVICES CORP.

James A. Dunn, Jr., P.E.
Senior Project Manager

Enclosure

pc: Neal Paul - Camp Lejeune, NC (w/enclosures)
Linda Saksvig - Navy, Norfolk, VA (w/enclosures)
Randy Smith - OHM Job Site at Camp Lejeune (w/enclosures)

**SOIL AND GROUNDWATER REMEDIATION
OPERABLE UNIT NO. 2, SITES 6 AND 82
MCB CAMP LEJEUNE, NORTH CAROLINA
RAC CONTRACT NO. N62470-93-D-3032
DELIVERY ORDER NO. 0015**

**JET MIXING EQUIPMENT
ADDENDUM NO. 2
RFQ NO. 16032-79090
DATED: DECEMBER 6, 1994**

Listed below are the changes and clarifications for RFQ No. 16032-79090 that make up Addendum No.2. The Bidder as required in RFQ No. 16032-79090, by receipt of the Addendum, must be acknowledged in the space provided in the bid form for his/her bid to be based responsive.

Addendum Item	Location/Paragraph No.	Description of Change/Clarification
2.1	Drawing No. M-8, Sheet 42 of 83	Minimum water level in tank T-110 will be set 3" (inches) above Jet Mixing Pump suction at pump casing. Level control will stop jet pump on low water level.

By receipt of this Addendum No. 2, the Bidder agrees to incorporate all items listed into the requirements as stated and/or shown in RFQ No. 16032-79090.



**OHM Remediation
Services Corp.**

A Subsidiary of OHM Corporation

December 21, 1994

Lt. Steve Challeen
ROICC Jacksonville
1005 Michael Road
Camp Lejeune, NC 28542-2521

RE: Addendum No. 1
LANTDIV RAC Contract N62470-93-D-3032
Delivery Order No. 0015; MCB Camp Lejeune,
Effluent Tanks
RFQ No. 16032-15032

Dear Lt. Challeen:

Enclosed herewith please find one copy of the Addendum No. 1 package for Effluent Tanks for the Groundwater Treatment Building on Lot 203.

If you should have any questions regarding the enclosed, please do not hesitate to contact us.

Very truly yours,

OHM REMEDIATION SERVICES CORP.

James A. Dunn, Jr., P.E.
Senior Project Manager

Enclosure

pc: Neal Paul - Camp Lejeune, NC (w/enclosures)
Linda Saksvig - Navy, Norfolk, VA
Randy Smith - OHM Job Site at Camp Lejeune (w/enclosures)

**SOIL AND GROUNDWATER REMEDIATION
OPERABLE UNIT NO. 2, SITES 6 AND 82
MCB CAMP LEJEUNE, NORTH CAROLINA
RAC CONTRACT NO. N62470-93-D-3032
DELIVERY ORDER NO. 0015**

**EFFLUENT TANKS
ADDENDUM NO. 1
RFQ NO. 16032-15032
DATED: DECEMBER 21, 1994**

Listed below are the changes and clarifications for RFQ No. 16032-15032 that make up Addendum No. 1. The Bidder as required in RFQ No. 16032-15032, by receipt of the Addendum, must be acknowledged in the space provided in the bid form for his/her bid to be based responsive.

Addendum Item	Location/Paragraph No.	Description of Change
1.1	Process Data Sheet for tanks, drums, and towers (Tanks T-240 and T-205)	Delete 24" dia. side manway in it's entirety and provide (1) one only 24" dia. manway on top of tanks T-240 and T-205.

By receipt of this Addendum No. 1, the Bidder agrees to incorporate all items listed into the requirements as stated and/or shown in RFQ No. 16032-15032.