

Minneapolis Water Works
Engineering Section
4300 Marshall Street N.E.
Minneapolis, MN 55421
[612] 788-9033

minneapolis

city of lakes

N91192.AR.000060
NIROP FRIDLEY
5090.3a

August 8, 1988

REC'D RMT 8-11-88

Mr. Scott Miller
R.M.T.
Suite 124
1406 E. Washington Avenue
Madison, WI 53703

Dear Mr. Miller:

The Minneapolis Water Works would like to have any River discharge from the proposed Navy pumpout program downstream of our intakes. The use of our 12" storm sewer line to accomplish this should be considered as a last resort. The Minneapolis Water Works would have to completely review the proposed system and approve of its use for this application. Provisions would have to be made, either manual or automatic, to stop this pumpout flow or valve it to the sanitary sewer during all significant rainfalls. The obvious negative aspect of this system, from our perspective, is that it is not in our control.

Please keep me informed on this problem.

Very truly yours,



Jay R. Whitaker, P.E.
Engineer II

JRW:gmp

copy - George Kroening
Jim F. Hayek
Adam Kramer
Larry Cole