

To: smtp[john.betcher@pca.state.mn.us]
SMTP [BLOOM.THOMAS@EPAMAIL.EPA.GOV]
SMTP [DAVID.DOUGLAS@PCA.STATE.MN.US]
Cc:
Bcc:
From: David M Cabiness@Code 18@NAVFAC EFDSOUTH
Subject: PRETREATMENT BYPASS - NIROP FRIDLEY
Date: Wednesday, March 29, 1995 9:39:46 EST
Attach:
Certify: N
Forwarded by:

THE FOLLOWING IS SUBMITTED FOR YOUR INFORMATION. ON WEDNESDAY 28 MARCH 1995
THE PRETREATMENT SYSTEM FOR THE GROUNDWATER CONTAINMENT SYSTEM AT NOROP
FRIDLEY WAS BYPASSED. THE FOLLOWING WELL FLOWS WERE RECORDED.

	AT-1A	AT-2	AT-3A	AT-4	TOTAL
PRIOR TO BYPASS (GPM)	39	45	198	32	314
AFTER BY PASS (GPM)	65 75	90 95	204	88	447 462
DESIGN FLOW (GPM)	75	125	250	125	575
% OF DESIGN FLOW	87%	72%	82%	70%	78%

I WILL KEEP YOU INFORMED AS DEVELOPMENTS OCCUR AT THE RANCH.