



STATE OF CONNECTICUT
DEPARTMENT OF ENVIRONMENTAL PROTECTION



9-26-1994
IX-26-94

Tim Evans
Halliburton NUS Corporation
993 Old Eagle School Road, Suite 415
Wayne, Pennsylvania 19087-1710

Mr. Evans:

This office has reviewed the Work Plan for Waste Oil Tank No. 10 and Building 325 No. 2 Fuel Oil (August 1994) and the Site Characterization Report for Waste Oil Tank #5, both for the Naval Submarine Base, Groton, CT.

Both the work plan and the characterization report appear satisfactory, provided flame ionization detectors are used instead of photoionization detectors. FIDs are more sensitive to semi-volatiles and should be used consistently throughout the investigation and remediation project.

Signed,

G. Scott Deshefy
Supervisory Environmental Analyst
UST Enforcement Program