

4/22/08 - 00695

Staszak, Janna/VBO

From: Reisch, Timothy A CIV NAVFAC MID ATLANTIC [timothy.reisch@navy.mil]
Sent: Tuesday, April 22, 2008 4:14 PM
To: Staszak, Janna/VBO
Subject: FW: Site 5 backfill Material Stockpiling work plan

Janna,
The Navy would prefer the use of silt fence vs. bales around the stockpiles.
Thanks - Tim

-----Original Message-----

From: Revell, Bryan C CIV NF ENVIRONMENTAL MGMT DIV, NSN
Sent: Tuesday, April 22, 2008 1:08 PM
To: Reisch, Timothy A CIV NAVFAC MID ATLANTIC
Subject: Site 5 backfill Material Stockpiling work plan

Tim,
I have reviewed the draft site plan for the subject work. I have no issue with the SWPPP and the Erosion and Sediment Controls are satisfactory, but I would like to see the use of silt fencing in lieu of hay bales. I feel that these controls would be more effective given the amount of soil to be disturbed and stockpiled. If you have any questions please let me know.

Bryan Revell

Stormwater Construction Compliance
Environmental Code OPNEEV
9742 Maryland Ave.
Bldg. N-26 Rm 3208
Norfolk, VA 23511

Phone (757) 445-1184
Fax (757) 444-5822
DSN 565-1184
Cell (757) 617-6399
bryan.revell@navy.mil