

N60200.AR.000660
NAS CECIL FIELD, FL
5090.3a

LETTER REGARDING DISCHARGE FROM ABANDONED UNDERGROUND HEATING OIL
TANK AT ENLISTED MEN QUARTER 431 NAS CECIL FIELD FL
6/21/1995
NAS CECIL FIELD



DEPARTMENT OF THE NAVY

NAVAL AIR STATION
CECIL FIELD, FLORIDA 32113-5000

5090
18410.3
June 21, 1995

City of Jacksonville
Bio-Environmental Division
Attn: Mr. Gerald Young
Towncentre-Suite 412
421 West Church Street
Jacksonville, Fl 32202-4111

Dear Mr. Young:

This letter is to confirm the report made to you by Ms. Ursula Klimas, June 21, 1995, concerning a discharge from an abandoned non-regulated 500 gallon underground heating oil tank, located at Enlisted Men Quarter 431. The release was discovered when the tank was removed. Enclosure (1) is F.A.C. 62-761.900(1), Discharge Reporting Form, for this release.

The tank, abandoned approximately 15 to 20 years ago, was found filled with oily rain water. The fill pipe had been removed, this allowed groundwater to entered the tank displacing the oil into the surrounding soil. All of the excessively contaminated soil could not be removed as it was saturated with water from the resent rains. A Contamination Assessment will be performed.

If you have any questions concerning this matter, please contact Ms. Ursula Klimas at (904) 778-6040.

Sincerely,

A handwritten signature in black ink, appearing to read "J. LLOYD CREWS", is written over a horizontal line.

J. LLOYD CREWS
Environmental Director
Staff Civil Engineer
By Direction of
the Commanding Officer

cc:
FDEP, Jacksonville (Mr. Kenton Brown)
FDEP, Tallahassee
COMNAVAVNACTS JAX (N3)