N60200.AR.002433
NAS CECIL FIELD, FL
5090.3a

LIMITED CLOSURE SUMMARY REPORT FOR BUILDING 15A DIESEL UNDERGROUND STORAGE TANK G15-U NAS CECIL FIELD FL

5/18/2000

NAVAL FACILITIES ENGINEERING COMMAND SOUTHERN DIVISION

Department of Environmental Protection

Twin Towers Office Building♦2600 Blair Stone Road♦Tallahassee, Florida 32399-2400

DEP Form 62-761.900(8)
Form Title: Limited Closure Summary Report
Effective Date: July 13, 1998

Limited Closure Summary Report

This form is required for facilities that have sites with documented contamination requiring a site assessment in accordance with Chapter 62-770, F.A.C. This includes those facilities that are eligible for the Early Detection Incentive Program (EDI), the Florida Petroleum Liability and Restoration Insurance Program (FPLRIP), and the Petroleum Cleanup Participation Program (PCPP), pursuant to Sections 376.3071 and 376.3072, F.S. Documentation of procedures followed, and results obtained during closure shall be reported in this form, along with any attachments. This form shall be submitted to the County within 60 days of completion of the closure in accordance with Section A of the "Storage Tank System Closure Assessment Requirements."

Complete All Applicable Blanks. Please Print or Type

General Information

(Tank # G15-U)

Date 5/18/00	FDEP Facility ID Number 16-85-07293	County Duval
Facility Name Naval Air Station Cecil Field	Facility Telephone #: ( )	
Facility Address: 13200 Normandy Blvd., Building 15A		
Owner or Operator Name: U.S. Government/U.S. Navy	Owner/Operator phone #: (904) 778-5440)	
Mailing Address: Caretaker Site Office, South Div NAVFACENGCOM P.O. Box 150853 Jacksonville, FL 32215-0853		

Storage Tank System Closure Information

1. Were the storage tanks(s): (Check one or both)

☐ Aboveground	☒ Underground 1,000-gal	

2. General System Information

Types of Products Stored: Diesel	Number of Tanks Closed 1	Age(s) of Tanks unk.

3. Was the Limited Closure Summary Report Performed as a Result of: (check one or more)

☒ Tank Systems Removal?	☐ Spill Containment Installation?	☐ Change in Storage to a Non-Regulated Substance?
☐ Tank Systems Closed in Place?	☐ Dispenser Liners Installation?	☐ Release Prevention Barrier Installation?
☐ Piping Sump Installation?	☐ Secondary Containment Installation?	☐ Other? (please explain)

4. Please Check Yes or No to the following:

a. Was there previously reported contamination discovered on site? If yes, was	☐ Yes	☒ No
1. A Discharge Report Form submitted to the County?	☐ Yes	☐ No
2. An investigation performed in accordance with Rule 62-761.820, F.A.C.?	☐ Yes	☐ No
b. Is the depth to groundwater less than 20 feet?	☒ Yes	☐ No
c. Are there monitoring wells on site? If yes, were they	☒ Yes	☐ No
1. Groundwater monitoring wells?	☒ Yes	☐ No
2. Vapor monitoring wells?	☐ Yes	☒ No
3. Used for closure assessment sampling?	☐ Yes	☒ No
4. Properly closed?	☐ Yes	☒ No
5. Retained for site assessment purposes?	☒ Yes	☐ No
d. If tanks were replaced, were contaminated soils returned to the tank excavation?	☐ Yes	☒ No

[signature]	[signature]	
Signature of owner or operator	Signature of person performing Limited Closure Assessment	Name of person performing Limited Closure Assessment
(date) 5/24/00	(date) 5/18/00	Affiliation Navy RAC

Printed on recycled paper.

Florida Department of Environmental Protection
Twin Towers Office Bldg.•2600 Blair Stone Road•Tallahassee, Florida 32399-2400

DEP Form #	62-761.900(5)
Form Title:	UST Contractor Form
Effective Date:	July 13, 1998

Underground Storage System Installation and Removal Form for Certified Contractors

Pollutant Storage Systems Contractor as defined in Section 489.113, Florida Statutes (certified contractors as defined in Section 62-761.200, Florida Administrative Code) shall use this form to certify that the installation, replacement or removal of the underground storage tank system(s) located at the address listed below was performed in accordance with Department Reference Standards. This includes system components such as dispenser liners, piping sumps, and overfill protection devices.

(Tank # G15-4)

General Facility Information

Facility Name: Naval Air Station Cecil Field	DEP Facility Identification No.: 16-85-07293
Street Address (physical location): 13200 Normandy Blvd., Building 15 A	
County: Duval	Telephone #: ( ) N/A
Owner Name: U.S. Government / U.S. Navy	Telephone #: (904) 778-5440
Owner Address: Caretaker Site Office, SouthDiv NAVFACENGCOM, P.O. Box 150853 Jacksonville, FL 32215-0853	

Storage Tank System Information

Number of Tanks Installed: N/A	Number of Tanks Removed: 1-1,000-gal UST
Date Work Initiated: 9/20/99	Date Work Completed: 9/21/99
Tank(s) Manufactured by: N/A	
Description of work Completed: Removal of one (1) 1,000-gal Diesel UST and associated piping.	

Certification

I hereby certify and attest that I am familiar with the facility that is registered with the Florida Department of Environmental Protection; that to the best of my knowledge and belief, the storage tank system installation, replacement or removal at this facility was conducted in accordance with Chapter 489, Florida Statutes, Section 376.303, Florida Statutes, and Chapter 62-761, Florida Administrative Code, and its adopted reference standards and documents for underground storage tank systems.

Joseph Scech (Type or Print) Certified Pollutant Tank Contractor Name	PC-C056763 PSSC Number Pollutant Storage Systems Contractor License Number
Certified Tank Contractor Signature	5/12/00 Date
Field Supervisor Name	5-12-00 Date

The owner or operator of the facility must register the tanks with the Department upon completion of the installation. The installer must submit this form to the County no more than 30 days after the completion of installation, replacement, or removal of a storage tank