

N60200.AR.002435
NAS CECIL FIELD, FL
5090.3a

LIMITED CLOSURE SUMMARY REPORT FOR BUILDING 339 UNDERGROUND STORAGE
TANKS 339-TC1 AND 339-TC2 NAS CECIL FIELD FL
5/18/2000
NAVAL FACILITIES ENGINEERING COMMAND SOUTHERN DIVISION



Department of Environmental Protection

Twin Towers Office Building • 2600 Blair Stone Road • Tallahassee, Florida 32399-2400

DEP Form 62-761.900(8)
Form Title: Limited Closure
Summary Report
Effective Date: July 13, 1998

Limited Closure Summary Report

This form is required for facilities that have sites with documented contamination requiring a site assessment in accordance with Chapter 62-770, F.A.C. This includes those facilities that are eligible for the Early Detection Incentive Program (EDI), the Florida Petroleum Liability and Restoration Insurance Program (FPLRIP), and the Petroleum Cleanup Participation Program (PCPP), pursuant to Sections 376.3071 and 376.3072, F.S. Documentation of procedures followed, and results obtained during closure shall be reported in this form, along with any attachments. This form shall be submitted to the County within 60 days of completion of the closure in accordance with Section A of the "Storage Tank System Closure Assessment Requirements."

Complete All Applicable Blanks. Please Print or Type

General Information

(Tank #s, 339-TC1; 339-TC2)

Date	5/18/00	FDEP Facility ID Number	16-85-07293	County	Duval
Facility Name	Naval Air Station Cecil Field			Facility Telephone #:	()
Facility Address:	13200 Normandy Blvd., Building 339				
Owner or Operator Name:	U.S. Government / U.S. Navy		Owner/Operator phone #:	(904) 778-5440	
Mailing Address:	Caretaker Site Office, South Div NAVFACENGCOM P.O. Box 150853 Jacksonville, FL 32215-0853				

Storage Tank System Closure Information

1. Were the storage tanks(s): (Check one or both)

<input type="checkbox"/> Aboveground	<input checked="" type="checkbox"/> Underground	2 - 20,000 gal
--------------------------------------	---	----------------

2. General System Information

Types of Products Stored:	JP-5	Number of Tanks Closed	2	Age(s) of Tanks	unk.
---------------------------	------	------------------------	---	-----------------	------

3. Was the Limited Closure Summary Report Performed as a Result of: (check one or more)

<input checked="" type="checkbox"/> Tank Systems Removal?	<input type="checkbox"/> Spill Containment Installation?	<input type="checkbox"/> Change in Storage to a Non-Regulated Substance?
<input type="checkbox"/> Tank Systems Closed in Place?	<input type="checkbox"/> Dispenser Liners Installation?	<input type="checkbox"/> Release Prevention Barrier Installation?
<input type="checkbox"/> Piping Sump Installation?	<input type="checkbox"/> Secondary Containment Installation?	<input type="checkbox"/> Other? (please explain)

4. Please Check Yes or No to the following:

a. Was there previously reported contamination discovered on site? If yes, was	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
1. A Discharge Report Form submitted to the County?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
2. An investigation performed in accordance with Rule 62-761.820, F.A.C.?	<input type="checkbox"/> Yes	<input type="checkbox"/> No
b. Is the depth to groundwater less than 20 feet?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
c. Are there monitoring wells on site? If yes, were they	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
1. Groundwater monitoring wells?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
2. Vapor monitoring wells?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
3. Used for closure assessment sampling?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
4. Properly closed?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No
5. Retained for site assessment purposes?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No
d. If tanks were replaced, were contaminated soils returned to the tank excavation?	<input type="checkbox"/> Yes	<input checked="" type="checkbox"/> No

[Signature]

[Signature]

Signature of owner or operator


Signature of person performing Limited Closure Assessment

Name of person performing Limited Closure Assessment

(date) 5/24/00

(date) 5/18/00

Affiliation Navy RAC



Underground Storage System Installation and Removal Form for Certified Contractors

Pollutant Storage Systems Contractor as defined in Section 489.113, Florida Statutes (certified contractors as defined in Section 62-761.200, Florida Administrative Code) shall use this form to certify that the installation, replacement or removal of the underground storage tank system(s) located at the address listed below was performed in accordance with Department Reference Standards. This includes system components such as dispenser liners, piping sumps, and overfill protection devices.

General Facility Information

339-TC1
(Tanks # 339-TC2)

Facility Name: <u>Naval Air Station Cecil Field</u>	DEP Facility Identification No.: <u>16-85-07293</u>
Street Address (physical location): <u>13200 Normandy Blvd., Building 339</u>	
County: <u>Duval</u>	Telephone #: () <u>N/A</u>
Owner Name: <u>U.S. Government / U.S. Navy</u>	Telephone #: <u>(904) 778-5440</u>
Owner Address: <u>Caretaker Site Office, South Div NAVFACENGLCOM, P.O. Box 150853 Jacksonville, FL 32215-0853</u>	

Storage Tank System Information

Number of Tanks Installed: <u>N/A</u>	Number of Tanks Removed: <u>2 - 20,000 gal USTs</u>
Date Work Initiated: <u>9/24/99</u>	Date Work Completed: <u>10/5/99</u>
Tank(s) Manufactured by: <u>N/A</u>	
Description of work Completed: <u>Removal of two (2) 20,000-gal JP-5 USTs and associated piping</u>	

Certification

I hereby certify and attest that I am familiar with the facility that is registered with the Florida Department of Environmental Protection; that to the best of my knowledge and belief, the storage tank system installation, replacement or removal at this facility was conducted in accordance with Chapter 489, Florida Statutes, Section 376.303, Florida Statutes, and Chapter 62-761, Florida Administrative Code, and its adopted reference standards and documents for underground storage tank systems.

Joseph Scech
(Type or Print)
Certified Pollutant Tank Contractor Name

PC-C056763
PSSC Number
Pollutant Storage Systems
Contractor License Number

[Signature]
Certified Tank Contractor Signature

5/12/00
Date

Allen J. Job
Field Supervisor Name

5-12-00
Date

The owner or operator of the facility must register the tanks with the Department upon completion of the installation. The installer must submit this form to the County no more than 30 days after the completion of installation, replacement, or removal of a storage tank