

N60200.AR.003058
NAS CECIL FIELD, FL
5090.3a

EMAIL REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
REVIEW OF FIRST QUARTER 2001 OPERATIONS AND MAINTENANCE STATUS REPORT
FOR BUILDING 9 FORMER TANKS 9L1 AND 9L2 NAS CECIL FIELD FL
8/31/2001
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

Jonnet, Mark

From: Grabka, David [David.Grabka@dep.state.fl.us]
Sent: Friday, August 31, 2001 1:51 PM
To: Debbie Vaughn-Wright (E-mail); Mark Davidson (E-mail); Speranza, Mark; Jonnet, Mark; Nick Ugolini (E-mail); Sam Ross (E-mail); Scott Glass (E-mail)
Cc: Bahr, Tim
Subject: Operation and Maintenance Status Report, 1st Quarter 2001, Building 9, Former Tanks 9L1 and 9L2

Team,

I have reviewed the Operations and Maintenance Status Report, 1st Quarter 2001, Nutrient Injection System, Building 9, Former Tanks 9L1 and 9L2, Naval Air Station Cecil Field, dated August 2001 (received August 15, 2001, CD version received August 23, 2001), prepared and submitted by CH2M Hill Constructors, Inc. The report is adequate for its intent. I concur with the consultant's recommendation to continue operating the system and maximizing the injection around well CEF-9-9S. This is to be accomplished by diverting all flow equally between injection wells CEF-9-I3 and CEF-9-I4. I would recommend that CEF-9-I2 be looked at as well as it is also in the vicinity of well CEF-9-9S. The system has apparently been quite successful in reducing groundwater contaminant concentrations at this site.

Sincerely,

David P. Grabka
FDEP Remedial Project Manager
(850)921-9991 (phone)
(850)922-4939 (fax)