

N60200.AR.003282
NAS CECIL FIELD, FL
5090.3a

LETTER REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
COMMENTS ON DRAFT SOURCE REMOVAL REPORT FOR BUILDING 82 TANK G82 NAS
CECIL FIELD FL
3/30/2002
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

March 30, 2001

Mr. Nick Ugolini
Code 1843 (UST RPM)
Southern Division
Naval Facilities Engineering Command
Post Office Box 190010
North Charleston, South Carolina 29419-9010

RE: Draft Source Removal Report, Building 82, Tank G82, Naval
Air Station Cecil Field, Jacksonville, Florida

Dear Mr. Ugolini:

I have completed the review of the Draft Source Removal Report, Building 82, Tank G82, Naval Air Station Cecil Field, dated March 2001 (received March 21, 2001), prepared and submitted by CH2M Hill Constructors, Inc. I have the following comments that should be addressed in the final version of the report:

- (1) The titles for Figures 1-2 and 2-1 are reversed.
- (2) On Table 2-1, OVA soil vapor data are missing for sample locations 10, 11 and 12. Also, in column 1 of the table, the reader should be referred to Figure 2-1 in order to review the sample locations.
- (3) The soil excavation activities were accomplished adequately within the constraints of the site layout. Contaminated soil apparently remains beneath the concrete aircraft parking apron to the east and the foundation of Building 82 to the west. Contaminated soil in these areas could not be excavated without compromising the integrity of the structures. This remaining contaminated soil may be addressed in the future either by remedial actions or institutional controls.

The Draft Source Removal Report should address the comments above and be finalized. A Site Assessment Report Addendum should be prepared to address contaminated groundwater at the site and discuss the Navy's intentions for the contaminated soil that remains beneath the aircraft parking apron and Building 82.