

N60200.AR.002960
NAS CECIL FIELD, FL
5090.3a

LETTER REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
APPROVAL OF SOURCE REMOVAL REPORT FOR UNDERGROUND STORAGE TANK
G231LS REMOVAL AT BUILDING 231 NAS CECIL FIELD FL
5/25/2001
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

May 25, 2001

Mr. Nick Ugolini
Code 1843 (UST RPM)
Southern Division
Naval Facilities Engineering Command
Post Office Box 190010
North Charleston, South Carolina 29419-9010

RE: Source Removal Report, Underground Storage Tank Removal at
Building 231, Tank G231LS, Naval Air Station Cecil Field,
Jacksonville, Florida

Dear Mr. Ugolini:

I have completed the review of the Source Removal Report, Underground Storage Tank Removal at Building 231, Tank G231LS, Naval Air Station Cecil Field, dated April 2001 (received April 24, 2001), prepared and submitted by CH2M Hill Constructors, Inc. The tank closure was conducted in accordance with Chapter 62-761, Florida Administrative Code. The report adequately documents the excavation and disposal of 7 tons of contaminated soil during tank closure activities. As soil and groundwater contamination do not currently exist at this site, you are not required to conduct further site assessment in accordance with Chapter 62-770, Florida Administrative Code.

If I can be of any further assistance with this matter, please contact me at (850) 488-3693.

Sincerely,

David P. Grabka
Remedial Project Manager

cc: Scott Glass, Southern Division
Debbie Vaughn-Wright, USEPA Region 4
Mark Speranza, TetraTech NUS, Pittsburgh
Sam Ross, CH2M Hill Constructors, Inc.
Mike Fitzsimmons, FDEP Northeast District

TJB

JJC

ESN