

N60200.AR.002983
NAS CECIL FIELD, FL
5090.3a

LETTER REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
REVIEW OF FIRST SEMI-ANNUAL YEAR 3 GROUNDWATER MONITORING REPORT FOR
DAY TANK 1 NAS CECIL FIELD FL
6/14/2001
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

June 14, 2001

Mr. Nick Ugolini
Code 1843 (UST RPM)
Southern Division
Naval Facilities Engineering Command
Post Office Box 190010
North Charleston, South Carolina 29419-9010

RE: Groundwater Monitoring Report, 1st Semi-Annual, Year 3 for
Day Tank 1, Naval Air Station Cecil Field, Jacksonville,
Florida

Dear Mr. Ugolini:

I have completed the review of the Groundwater Monitoring Report, 1st Semi-Annual, Year 3 for Day Tank 1, Naval Air Station Cecil Field, dated May 2001 (received May 14, 2001), prepared and submitted by Tetra Tech NUS, Inc. I concur with the consultant's recommendation that the groundwater monitoring program may be discontinued pending the results of further site assessment at Day Tank 1 and Building 824A. While I concur that free product recovery should be implemented to address free product discovered in the vicinity of vapor extraction wells VEW-01 and VEW-02, I feel that further assessment work to determine the full extent of free product at the site should be conducted. Monitoring of the site should continue until funding has been provided to do further assessment work in the Day Tank 1 area.

If I can be of any further assistance with this matter, please contact me at (850) 488-3693.

Sincerely,

David P. Grabka
Remedial Project Manager

cc: Scott Glass, Southern Division
Debbie Vaughn-Wright, USEPA Region 4
Mark Speranza, TetraTech NUS, Pittsburgh
Sam Ross, CH2M Hill Constructors, Inc.
Mike Fitzsimmons, FDEP Northeast District

TJB

JJC

ESN