

N61165.AR.005121  
CNC CHARLESTON  
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND  
ENVIRONMENTAL CONTROL REVIEW OF UNDERGROUND STORAGE TANK (UST)  
ASSESSMENT REPORT DATED 27 AUGUST 1998 FOR BUILDING 758 (QUARTERS NH-A  
HOUSING) CNC CHARLESTON SC  
09/30/1998  
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



30 September 1998

2600 Bull Street  
Columbia, SC 29201-1708

COMMISSIONER:  
Douglas E. Bryant

BOARD:  
John H. Burriss  
Chairman

William M. Hull, Jr., MD  
Vice Chairman

Roger Leaks, Jr.  
Secretary

Mark B. Kent

Cyndi C. Mosteller

Brian K. Smith

Rodney L. Grandy

Department of the Navy  
Southern Division NFEC  
P.O. Box 190010  
North Charleston, SC 29419-9010  
Attn: Mr. Gabriel Magwood

Re: Underground Storage Tank Assessment Report dated 27 August 1998  
Building 758 (Quarters "NH A" Housing) (Site Identification # 15405-General File)  
Charleston Naval Complex/Charleston Naval Base  
Charleston, SC  
Charleston County

Dear Mr. Magwood:

The author has completed technical review of the referenced document. As submitted, the report provides a narrative describing closure activities and analytical results of environmental sampling conducted to determine if releases have occurred as a result of operation of the referenced vessel and/or associated piping system. The analytical results provided indicate that concentrations of BTEX and PAH compounds were not detected above established method detection limits in soil grab samples obtained from the UST excavation and/or piping run excavations. In this regard, the employed closure activities and sampling results appear to indicate that no additional endeavors for remedial actions and/or contaminant characterization are warranted for Building 758 at this time.


With consideration to the above comments, the Department has reviewed the referenced environmental data. Based on the information and analytical data submitted, the Department recognizes that the Department of the Navy and Charleston Naval Complex/Charleston Naval Base has adequately addressed the known environmental contamination identified on the property to date in accordance with the approved scope of work. Please note, this statement pertains only to the portion of the site addressed in the referenced report and does not apply to other areas of the site and/or any other potential regulatory violations. Further, the Department retains the right to request further investigation if deemed necessary.

Charleston Naval Complex/Charleston Naval Base  
30 September 1998  
page 2

Should you have any questions please contact me at (803) 734-5328.

Sincerely,

  
Paul L. Bristol, Hydrogeologist  
Groundwater Quality Section  
Bureau of Water

  
Tom Knight, Manager  
Groundwater Quality Section  
Bureau of Water

cc: Trident District EQC