

N61165.AR.005289
CNC CHARLESTON
5090.3a

FIRST QUARTER 2001 MONITORING REPORT FOR ZONE K BUILDING 2513 ABOVE
GROUND STORAGE TANKS 2513A AND 2513B (AST 2513A AND 2513B) WITH SOUTH
CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL REVIEW
LETTER CNC CHARLESTON SC
04/10/2001
CH2M HILL



10 April 2001

2600 Bull Street
Columbia, SC 29201-1708

COMMISSIONER:
Douglas E. Bryant

BOARD:
Bradford W. Wyche
Chairman

William M. Hull, Jr., MD
Vice Chairman

Mark B. Kent
Secretary

Howard L. Brilliant, MD

Brian K. Smith

Rodney L. Grandy

Larry R. Chewning, Jr., DMD

DEPARTMENT OF THE NAVY
SOUTHERN DIVISION NAVAL FEC
GABRIEL MAGWOOD
2155 EAGLE DRIVE
N. CHARLESTON SC 29406

RE: CNB - Zone K / Building 2513 - AST 2513-A & 2513-B
Site Identification # 00960
First Quarter 2001 Monitoring Report received 9 April 2001
Charleston County

Dear Mr. Magwood:

The Department has completed technical review of the referenced document. As submitted, the monitoring report outlines activities to assess hydrocarbon contamination in the vicinity of the former aboveground storage tanks.

Per the referenced document, soil boring 513SB00702 exhibited levels of Benzene, Naphthalene and other PAHs above established RBSL limits. As proposed in the CAP dated February 2001, soil excavation will be employed in an effort to eliminate the contamination. As outlined in the CAP approval, the Department must be provided a work plan identifying the extent of the excavation and outlining procedures for waste management prior to initiation of excavation activities. Please submit an excavation work plan no later than 31 May 2001.

Per the referenced report, further soil sampling in the vicinity of former AST B indicates that soil samples did not exceed the established RBSL limits. No further assessment or corrective action activities are warranted at this time. Due to the proximity of tanks A & B, issuance of a formal NFA letter will be postponed until activities around tank A are completed.

Should you have any questions please contact me at 803-898-3553 (office phone), 803-898-3795 (fax) or by e-mail bishopma@columb32.dhec.state.sc.us.

Sincerely,

Michael A. Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC
Brian R. Crawford, 1849 Ave. F, N. Charleston SC, 29405
Mihir Mehta, SCHDEC-BLWM
Technical File

SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL