

N61165.AR.005338
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF GROUNDWATER SAMPLING REPORT
RECEIVED 17 MARCH 2003 AND NO FURTHER ACTION (NFA) FOR BUILDING NS-2 CNC
CHARLESTON SC
03/17/2003
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



17 March 2003

2600 Bull Street
Columbia, SC 29201-1708

COMMISSIONER:
C. Earl Hunter

BOARD:
Bradford W. Wyche
Chairman

Mark B. Kent
Vice Chairman

Howard L. Brilliant, MD
Secretary

Carl L. Brazell

Louisiana W. Wright

L. Michael Blackmon

Larry R. Chewning, Jr., DMD

Commander
NAVFACENGCOM Southern Division
Attn: Code ES24 (Gabriel Magwood)
P.O. Box 190010
North Charleston, SC 29419-9010

Re: CNB – NS2
Site Identification # 17595
Groundwater Sampling Report received 17 March 2003
No Further Action
Charleston County

Dear Mr. Magwood:

The Department has reviewed the referenced assessment report. As submitted, the report documents current and historical efforts to monitor soil and groundwater for hydrocarbon contamination at the subject site. Based on this review, it appears that maximum contaminant levels are not currently exceeded in soil and/or groundwater at the site.

Based on the information and analytical data submitted, the Department recognizes that the Department of the Navy has adequately addressed the known environmental contamination identified on the property to date in accordance with the approved scope of work. Consequently, no further investigation is required at this time. Please note, this statement pertains only to the portion of the site addressed in the referenced report and does not apply to other areas of the site and/or any other potential regulatory violations. Furthermore, the Department retains the right to request further investigation if deemed necessary.

The monitoring well(s) may be permanently abandoned by a certified well driller licensed in South Carolina in accordance with the South Carolina Well Standards and Regulations, R.61-71 or properly maintained. Should you choose to abandon the well, please submit a well abandonment record to my attention within 30 days of abandonment. Should you choose to properly maintain the monitoring well, please notify me within 14 days of this correspondence.

Should you have any questions, please contact me at 803-898-3553 (office phone), 803-898-2893 (fax) or bishopma@dhec.sc.gov.

Sincerely,

Michael Bishop, Hydrogeologist
Groundwater Quality Section
Bureau of Water

Tom Knight, Manager
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC
Jerry Stamps – BLWM
Brian Crawford, 1849 Ave. F, N. Charleston SC 29405
Technical File