

N61165.AR.005363
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF UNDERGROUND STORAGE TANK (UST)
ASSESSMENT REPORT DATED 1 JUNE 1998 FOR QUARTERS L HOUSING CNC
CHARLESTON SC
07/15/1998
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



15 July 1998

PROMOTE PROTECT PROSPER

2600 Bull Street
Columbia, SC 29201-1708

COMMISSIONER:
Douglas E. Bryant

BOARD:
John H. Burriss
Chairman

William M. Hull, Jr., MD
Vice Chairman

Roger Leaks, Jr.
Secretary

Mark B. Kent

Cyndi C. Mosteller

Brian K. Smith

Rodney L. Grandy

Department of the Navy
Southern Division NFEC
P.O. Box 190010
North Charleston, SC 29419-9010
Attn: Mr. Gabriel Magwood

Re: Underground Storage Tank Assessment Report dated 1 June 1998
Quarters "L" Housing (Site Identification # 15405-General File)
Charleston Naval Complex/Charleston Naval Base
Charleston, SC
Charleston County

Dear Mr. Magwood:

The author has completed technical review of the referenced document. As submitted, the report provides a narrative describing closure activities and analytical results of environmental sampling to determine if releases have occurred as a result of operation of the referenced vessel and/or associated piping system. The analytical results provided indicate reportable concentrations of BTEX compounds were detected in soil grab samples obtained from the UST excavation and the piping run excavation. The reported concentrations are below levels proposed in the SCAP (Soil Corrective Action Plan, amended July 1997). Based on review of the employed closure activities and sampling results it appears that no additional endeavors for remedial actions and/or contaminant characterization is warranted for Quarters "L" Housing at this time. Please be aware this statement pertains only to the portion of the facility addressed in the referenced document and does not apply to other areas of the facility and/or any other potential regulatory violations. The Department retains the authority to request additional assessments and/or remedial endeavors, as appropriate, if future conditions or information warrant and are deemed necessary.

Should you have any questions please contact me at (803) 734-5328.

Sincerely,


Paul L. Bristol, Hydrogeologist
Groundwater Quality Section
Bureau of Water


Tom Knight, Manager
Groundwater Quality Section
Bureau of Water

cc: Trident District EQC



DEPARTMENT OF THE NAVY
SOUTHERN DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
P.O. BOX 190010
2155 EAGLE DRIVE
NORTH CHARLESTON, S.C. 29419-9010

NFA

Li 6.5.98
Lw 7.15.98

RECEIVED
JUN 4 1998
Code 1849
1 June 1998

Water Monitoring, Assessment &
Protection Division

Mr. Paul Bristol
South Carolina Department of Health
And Environmental Control
Division of Underground Storage Tank
2600 Bull Street
Columbia, SC 29201


**UST ASSESSMENT REPORTS FOR CHARLESTON NAVAL COMPLEX,
CHARLESTON, SC**

Dear Mr. Bristol:

Enclosed are the Assessment Reports for the closure of Underground Storage Tanks A, K, L, M, N, Y, 220 and 3909 located at the Charleston Naval Complex, Charleston, SC.

If you have any questions please contact me at (843) 820-7307.

Sincerely,


GABRIEL L. MAGWOOD
Petroleum/UST

Encl:
(1) Assessment Reports

As to be changed
15405