

N61165.AR.005413  
CNC CHARLESTON  
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND  
ENVIRONMENTAL CONTROL REVIEW OF CORRECTIVE ACTION REPORT RECEIVED 30  
DECEMBER 2005 FOR ZONE H SITE 4 BUILDING 640 CNC CHARLESTON SC  
08/11/2006  
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

BOARD:  
Elizabeth M. Hagood  
Chairman  
Edwin H. Cooper, III  
Vice Chairman  
Steven G. Kisner  
Secretary



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment*

BOARD:  
Henry C. Scott  
Paul C. Aughtry, III  
Glenn A. McCall  
Coleman F. Buckhouse, MD

11 August 2006

Dudley Patrick  
BRAC PMO SE  
PO Box 190010  
North Charleston, SC 29419-9010

RE: CNB - Zone H, Site 4/ Building 640 (Heating Oil UST)  
**Site Identification # 00955**  
Corrective Action Report received 30 December 2005  
Charleston County

Dear Mr. Patrick:

The Department has completed technical review of the referenced document. Interpretation of the analytical data provided in the referenced report indicates that chemicals of concern remain above established Risk-Based Screening Levels and MCLs.

The Department concurs with the conclusions as presented in the report and passive free product recovery and routine groundwater monitoring and reporting should continue. Given the limited aerial extent of the contamination and relatively shallow groundwater, CNB may wish to consider more proactive measures to deal with the contamination at Building 640.

Please submit the next monitoring report no later than 29 December 2006. Should you have any questions, please contact me at 803-898-3553 (office phone), 803-898-3795 (fax) or [bishopma@dhec.state.sc.us](mailto:bishopma@dhec.state.sc.us).

Sincerely,

Michael Bishop, Hydrogeologist  
Groundwater Quality Section  
Bureau of Water

cc: Region 7 District EQC  
Jerry Stamps-BLWM  
Andrew O'Connor, CH2MHILL, 1330 Kilo Street, N. Charleston, SC 29405  
Technical File