

N61165.AR.005477  
CNC CHARLESTON  
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND  
ENVIRONMENTAL CONTROL REVIEW OF REMEDIATION MONITORING REPORT  
RECEIVED 23 JULY 2004 FOR ZONE H AREA OF CONCERN 659 (AOC 659) ABOVE  
GROUND STORAGE TANK NS-14 (AST NS-14) CNC CHARLESTON SC  
07/23/2004  
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

BOARD:  
Elizabeth M. Hagood  
Chairman  
Mark B. Kent  
Vice Chairman  
Howard L. Brilliant, MD  
Secretary



C. Earl Hunter, Commissioner

*Promoting and protecting the health of the public and the environment.*

23 July 2004

BOARD:  
Carl L. Brazell  
Louisiana W. Wright  
L. Michael Blackmon  
Coleman F. Buckhouse, MD

Commander  
NAVFACENGCOM Southern Division  
Attn: Code ES24 (Gabriel Magwood)  
P.O. Box 190010  
North Charleston, SC 29419-9010

RE: AST NS 14 (AOC 659 – Zone H)  
**Site ID # 01311**  
Remediation Monitoring Report received 23 July 2004  
Charleston County

Dear Mr. Magwood:

The Department has completed technical review of the referenced document. Interpretation of the analytical data provided in the referenced report indicates that chemicals of concern remain above established Risk-Based Screening Levels and MCLs. The report also documents the continued presence of free product at this site.

The Department concurs with the conclusions as presented in the report and the Navy should submit a CAP for this site. The CAP should include a proposal for well installations to support both remedial efforts and definition of the contaminant plume. The CAP should also outline proposed active remediation strategies and present a timeframe for implementation.

The CAP should be submitted no later than 31 December 2004. Should you have any questions please contact me at 803-898-3553 (office phone), 803-898-3795 (fax) or by e-mail [bishopma@dhec.sc.gov](mailto:bishopma@dhec.sc.gov).

Sincerely,

Michael A. Bishop, Hydrogeologist  
Groundwater Quality Section  
Bureau of Water

cc: Trident District EQC  
Jerry Stamps – BLWM  
Darryl Gates, CH2MHILL, 1330 Kilo Street, N Charleston, SC 29405  
Technical File