

N61165.AR.005481  
CNC CHARLESTON  
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND  
ENVIRONMENTAL CONTROL REVIEW OF MONITORING AND EXCAVATION REPORT  
RECEIVED 27 MARCH 2002 FOR ZONE H SITE 44 ABOVE GROUND STORAGE TANK 601  
(AST 601) CNC CHARLESTON SC

08/05/2002

SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL



5 August 2002

500 Bull Street  
Columbia, SC 29201-1708

COMMISSIONER:  
Earl Hunter

BOARD:  
Madford W. Wyche  
Chairman

Mark B. Kent  
Vice Chairman

Edward L. Brilliant, MD  
Secretary

Earl L. Brazell

Louisiana W. Wright

Michael Blackmon

Terry R. Chewning, Jr., DMD

Commander  
NAVFACENGCOC Southern Division  
Attn: Code ES24 (Gabriel Magwood)  
P.O. Box 190010  
North Charleston, SC 29419-9010

Re: CNB – Zone H, Site 44 (AST 601)  
**Site Identification # 01537**  
Monitoring and Excavation Report received 27 March 2002  
Charleston County

Dear Mr. Magwood:

The Department has completed technical review of the referenced document. As submitted, the Monitoring and Excavation Report provides an outline of active corrective action activities conducted to remediate hydrocarbon contamination at the referenced facility.

Soil contamination in excess of established RBSL limits was defined and excavated per the CAP. Groundwater sampling activities indicated the presence of free phase petroleum in monitoring wells CNC44MW01 & CNC44MW04. The Department concurs with the recommendation of your contractor that free product continue to be removed from the affected monitoring wells and, once free product has been removed, establish a monitoring program. Please note that the Department retains the right to require additional monitoring points at the conclusion of remediation activities to verify remediation goals.

Please provide the Department with a free product removal report on a quarterly basis. The Department should receive the first free product removal report no later than 31 December 2002. Should you have any questions please contact me at 803-898-3553 (office phone), 803-898-2893 (fax) or by e-mail [bishopma@dhec.state.sc.us](mailto:bishopma@dhec.state.sc.us).

Sincerely,

Michael A. Bishop, Hydrogeologist  
Groundwater Quality Section  
Bureau of Water

cc: Trident District EQC  
Jerry Stamps, SCHDEC-BLWM  
Brian Crawford, 1849 Ave. F, N. Charleston SC, 29405  
Technical File