

N61165.AR.005571
CNC CHARLESTON
5090.3a

LETTER REGARDING SOUTH CAROLINA DEPARTMENT OF HEALTH AND
ENVIRONMENTAL CONTROL REVIEW OF ABOVE GROUND STORAGE TANK (AST)
ASSESSMENT REPORT DATED 3 FEBRUARY 1997 FOR BUILDING 1708 CNC
CHARLESTON SC
03/06/1997
SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

Mr. Gabriel L. Magwood
Southern Division NFEC
P.O. Box 190010
2155 Eagle Drive
North Charleston, South Carolina 29419-9010

Re: Aboveground Storage Tank Assessment Report dated (received) February 3, 1997
Building 1708 (DHEC Site Identification # 15405- General)
Charleston Naval Complex/Charleston Naval Base (CNB)
Charleston, SC
Charleston County


Date: March 6, 1997

Dear Mr. Magwood:

The author has completed technical review of the referenced document. As submitted, the report provides narrative describing the history and closure of the AST at the referenced location. Based on the lack of visible evidence demonstrating a release from the system during closure, it does not appear that additional assessment activities associated with the AST are warranted for this site. Please be aware that if in the future contamination is identified which is attributable to this site, additional assessment and/or remedial endeavors may be required, as appropriate.

Should you have any questions, please contact me at (803) 734-5328.

Sincerely,


Paul L. Bristol, Hydrogeologist
Groundwater Assessment and Development Section
Bureau of Water

cc: Trident District EQC



DEPARTMENT OF THE NAVY
SOUTHERN DIVISION
NAVAL FACILITIES ENGINEERING COMMAND
P.O. BOX 180010
2188 EAGLE DRIVE
NORTH CHARLESTON, S.C. 29418-8010

Li 2.19.97
Lo 3.11.97

5090
Code 1849
31 Jan 1997

RECEIVED

FEB 03 1997

Groundwater Assessment
and Development Section

Mr. Paul Bristol
South Carolina Department of Health
and Environmental Control
Ground-Water Protection Division
2600 Bull Street
Columbia, SC 29201

**UST ASSESSMENT REPORT FOR: UST 240, UST NH 1137-1 and NH 1137-2, NS
4-TNK -1, UST 1708 and NH 46 CHARLESTON NAVAL COMPLEX,
CHARLESTON, SC**


Dear Mr. Bristol:

Enclosed are the Assessment Reports for the closure of underground storage tanks 240,
NH 1137-1 and 2, NS 4-tnk-1, 1708 and NH 46 located at the Charleston Naval
Complex, Charleston, SC.

If you have any questions, please contact me at 803-820-7307.

UST 240 - 2.5.97 BUSTW
NH 1137 - 17754
AST 1708 - 15405 (General)
NS 4 - 17595 (Bldg NS 2)
NH 46 - 17755

Sincerely,


GABRIEL L. MAGWOOD
Petroleum/UST

Encl:
(1) UST Assessment Report