

## DEPARTMENT OF ENVIRONMENTAL RI

32212-000

19.01.00.0011

## NORTHEAST DISTRICT

26 BILLS ROAD  
JACKSONVILLE, FLORIDA 32207  
(904) 396-6959VICTORIA J. TSCHINKEL  
SECRETARYG. DOUG DUTTON  
DISTRICT MANAGER

11421 ✓

November 27, 1984

Mr. D. R. Spell, P.E.  
Head, Environmental Branch  
Department of the Navy  
Naval Facilities Engineering Command  
Post Office Box 10068  
Charleston, South Carolina 29411

Dear Mr. Spell:

Duval County - DW  
Jacksonville Naval Air Station

In response to your letter of November 9, 1984, the 3.0 mgd activated sludge sewage treatment facility at the Jacksonville Naval Air Station was designed for domestic wastewater treatment. Sections 17-6.05(1)(c) and 17-6.180(2)(c), Florida Administrative Code (FAC), specifically states that "the deliberate introduction of stormwater in any amount into collection/transmission systems designed solely for the introduction (and conveyance) of domestic/industrial wastewater...." are prohibited. Also, the acceptance of any waste which has not received necessary pretreatment or which contain materials or pollutants (other than normal domestic wastewater constituents) which may cause excessive corrosion or other deterioration of wastewater facilities due to chemical action or pH levels is also prohibited by Section 17-6.180(2)(d), FAC.


Interpretation of the above stated rules may negate any possibility of the acceptance of either stormwater or groundwater into the domestic or industrial wastewater collection transmission and treatment system. However, as I discussed with Mr. James Malone of your office, should you provide us with sufficient data to show that this waste can be adequately treated in a domestic waste treatment plant, we would consider the proposal further.

Mr. D. R. Spell, P.E.  
November 28, 1984  
Page 2

It would be inappropriate at this time (without the treatability information) to address any additional monitoring requirements which may be imposed on the treatment plant. It is recommended that you submit a proposed monitoring program with an explanation of the parameters chosen and frequency of sampling, for our review, when the treatability information is submitted.

If you have any questions, please contact this office.

Sincerely,

  
Jerry M. Owen, P.E.

 DJMO:dbr