

N60201.AR.000327
NS MAYPORT
5090.3a

LETTER REGARDING WATER USE RECORD FOR WELLS A THROUGH E FOR JANUARY
THROUGH JUNE 1996 NS MAYPORT FL
7/26/1996
NAVAL STATION MAYPORT

32228-000
19.01.00.0082

5090.8
5090.15
Ser N4E4/00162
26 JUL 1996

Ms. Gloria Lewis
Division of Permit Data Services
St. Johns River Water Management District
P.O. Box 1429
Palatka, FL 32178-1429

Subj: CONSUMPTIVE USE PERMIT #2-031-
0240ANG, REMEDIATION SYSTEM AT
NAVAL STATION MAYPORT

Dear Ms. Lewis:

Naval Station Mayport (NAVSTA) submits Water Use Record, Form EN-50, for wells A-E for January through June 1996 in accordance with subject permit requirements.

The forms have all been marked for "Comments" in Step 1 due to a problem with the system in February. The system froze, the weekend of February 3-4, rupturing the main discharge pump and destroying the individual well flow meters. The flow meter for well A had been replaced in January 1996, as referenced on the Form EN-50 for the September through December 1995 timeframe. The entire system was inoperable and no pumping occurred after the February freeze. Repairs on the system were completed the last week of June and new flow meters were installed for each well, hence, the June 0.0 meter readings. The system was turned back on the beginning of July and the next submittal of EN-50 forms will reflect the new flow meter readings. Steps have been taken to repair the lines such that no damage should occur during the next hard freeze.

If you have any questions regarding this subject, NAVSTA's point of contact is Cheryl Mitchell, N4E4, at 904-270-6730.

Sincerely,

ROBERT P. WALDEN
Lieutenant Commander, CEC, U.S. Navy
Staff Civil Engineer
By direction of
the Commanding Officer

Encl:

(1) Five Form EN-50

Copy to:
SJRWMD Jacksonville