



N00639 AR.000217  
MILLINGTON SUPPACT  
5090.3a

STATE OF TENNESSEE  
DEPARTMENT OF ENVIRONMENT AND CONSERVATION  
JACKSON ENVIRONMENTAL FIELD OFFICE  
362 CARRIAGE HOUSE DRIVE  
JACKSON, TENNESSEE 38305-2222

**CERTIFIED MAIL**

Z 034 327 280

June 5, 1995

Mr. Donald H. Litton  
Acting Public Works Officer  
N.A.S. - Memphis  
7800 Third Avenue  
Millington, Tennessee 38054-5045

RE: Production Well No. 1  
Emergency Activation

Dear Mr. Litton:

This office received your correspondence regarding the emergency activation of production well number one. This letter confirms our verbal approval to activate the well in an emergency situation should it arise.


If the situation is of short duration such as a fire or other temporary event it is likely that additional monitoring for volatile organic chemicals would not be warranted. If an event such as the failure of one of your existing production wells should occur resulting in the extended usage of well number one it is likely that at least quarterly monitoring of this well would be required. This office should be informed upon the occurrence of any event which would result in the activation of well number one and any decisions regarding monitoring requirements will be made at that time and would be based upon the nature of the situation.

Mr. Donald H. Litton  
June 5, 1995  
Page 2

If the well is activated you may initially experience increased levels of iron and manganese due to the unit being at rest for a period of time. If time would allow, the well could be purged for a short period of time before it is discharged into the filter plant.

If this office may be of additional assistance or if you have any further questions you may contact me at 901-661-6265.

Sincerely,



Brian T. Caton  
Assistant Manager  
Tennessee Division of Water Supply  
Jackson Field Office

BTC060795WS01

c: David Draughon, Central Office  
Ms. Tonya Barker, NAS  
Mr. Rob Williamson, NAS  
Mr. Jordan English, TDSF