

N00639.AR.002170
NSA MID SOUTH
5090.3a

TRANSMITTAL LETTER FOR U S NAVY INSPECTION FORMS FOR WELLS AT HOSPITAL
JUNE 1997 THROUGH NOVEMBER 1997 MILLINGTON SUPPACT TN
1/2/1998
MILLINGTON SUPPACT



DEPARTMENT OF THE NAVY
NAVAL SUPPORT ACTIVITY MEMPHIS
7800 3RD AVENUE
MILLINGTON, TENNESSEE 38054-5045

IN REPLY REFER TO

5090
Ser 0101 **000069**
20 JAN 1998

CERTIFIED MAIL P 295 473 777
RETURN RECEIPT REQUESTED

Mr. Ben Brantly
Environmental and Safety Designs, Inc.
5724 Summer Trees
Memphis, TN 38134

Dear Mr. Brantly:

Enclosures (1) through (6) are submitted for Naval Hospital, Millington.

If you need additional information, please contact Ms. Tonya Barker or Mr. Randy Wilson of the Public Works Department, Environmental Division, at 874-5461.

Sincerely,

DARRYL K. CREAMY
LCDR. CEC, USN
PUBLIC WORKS OFFICER
BY DIRECTION OF THE COMMANDING OFFICER
NAVAL SUPPORT ACTIVITY MEMPHIS

Encl:

- (1) U.S. Navy Monitoring Inspection Form for Wells at Hospital, June 1997
- (2) U.S. Navy Monitoring Inspection Form for Wells at Hospital, July 1997
- (3) U.S. Navy Monitoring Inspection Form for Wells at Hospital, August 1997
- (4) U.S. Navy Monitoring Inspection Form for Wells at Hospital, September 1997
- (5) U.S. Navy Monitoring Inspection Form for Wells at Hospital, October 1997
- (6) U.S. Navy Monitoring Inspection Form for Wells at Hospital, November 1997

Copy to:
Commanding Officer
SOUTHNAVFACENCOM
(Code 1846)
2155 Eagle Drive
North Charleston, SC 29419-9010

US NAVY MONITORING INSPECTION FORM FOR WELLS AT HOSPITAL

Activity Name: NAVAL HOSPITAL MILLINGTON

Tank No.'s 106, 107

(1)		(2)	(3)	(4)	(5)		(6)		(7)		(8)	(9)
WELL PURGE		WELL ID NUMBER	PETROLEUM VAPOR PPM	WATER LEVEL		WATER DEPTH		SAMPLE TAKEN		VISUAL INSPECTION OF FREE PRODUCT THICKNESS TO 1/8"	PRINT NAME	
DATE	TIME			FT	IN	FT	IN	DATE	TIME			
7-29-97	1030	B-4	NA	2	4			7-30-97	1100	Slight sheen & streaks	Tim Turner	
7-29-97	1100	B-3		3	4			7-30-97	1100	Looks ok, Smells ok	Tim Turner	
7-29-97	1130	B-1		13	5	14	0	7-30-97	1130	Looks ok, Smells ok	Tim Turner	

- NOTES:
1. Wells are as follows: B1-27'5", B2-21'7", B3-22'9", B4-15'7"
 2. Depth measurements should be to the nearest 1/8" or 0.01'.
 3. Inspection equipment must be thoroughly decontaminated between wells.
 4. Evidence of free product shall be reported to PWD Environmental Division

REMARKS:

ENCLOSURE (2)

US NAVY MONITORING INSPECTION FORM FOR WELLS AT HOSPITAL

Activity Name: NAVAL HOSPITAL MILLINGTON

Tank No.'s 106, 107

(1)		(2)	(3)	(4)	(5)		(6)		(7)		(8)	(9)
WELL PURGE		WELL ID NUMBER	PETROLEUM VAPOR PPM	WATER LEVEL		WATER DEPTH		SAMPLE TAKEN		VISUAL INSPECTION OF FREE PRODUCT THICKNESS TO 1/8"	PRINT NAME	
DATE	TIME			FT	IN	FT	IN	DATE	TIME			
10-28-97	1305	B-1	43	13	1	14	7	10-30-97	1330	Low End Smells ok	Tom Turner	
10-29-97	1340	B-3	49	2	9	20	0	10-30-97	1345	Low End Smells ok	Tom Turner	
10-29-97	1410	B-4	307	2	0	13	7	10-30-97	1430	Slight Green + Foul odor	Tom Turner	

- NOTES: 1. Wells are as follows: B1-27'5", B2-21'7", B3-22'9", B4-15'7"
 2. Depth measurements should be to the nearest 1/8" or 0.01'.
 3. Inspection equipment must be thoroughly decontaminated between wells.
 4. Evidence of free product shall be reported to PWD Environmental Division

REMARKS: _____

EUC:(5)

