

N00639.AR.002171
NSA MID SOUTH
5090.3a

TRANSMITTAL LETTER FOR GROUNDWATER MONITORING REPORTS FROM FEBRUARY
1997 THROUGH APRIL 1997 AND GROUNDWATER MONITORING INSPECTION FORMS
FOR NAVAL HOSPITAL MILLINGTON SUPPACT TN
5/28/1997
MILLINGTON SUPPACT



DEPARTMENT OF THE NAVY
NAVAL SUPPORT ACTIVITY MEMPHIS
7800 3RD AVENUE
MILLINGTON, TENNESSEE 38054-5045

IN REPLY REFER TO

5090

Ser 0101/ **001123**

28 MAY 1997

**CERTIFIED MAIL
RETURN RECEIPT REQUESTED**

Mr. Ben Brantly
Environmental and Safety Designs, Inc.
5724 Summer Trees
Memphis, TN 38134

Dear Mr. Brantly:

Enclosures (1) through (3) are the February 1997, March 1997, and April 1997, groundwater monitoring inspection forms for Naval Hospital, Millington.

If you need additional information, please contact Ms. Tonya Barker or Mr. Randy Wilson of the Public Works Department, Environmental Division, at 874-5461.

Sincerely,

DARRYL K. CREASY
LCDR, CEC, USN
PUBLIC WORKS OFFICER
BY DIRECTION OF THE COMMANDING OFFICER
NAVAL SUPPORT ACTIVITY MEMPHIS

Encl:

- (1) U.S. Navy Monitoring Inspection Form for Wells at Hospital, February 1997
- (2) U.S. Navy Monitoring Inspection Form for Wells at Hospital, March 1997
- (3) U.S. Navy Monitoring Inspection Form for Wells at Hospital, April 1997

Copy to:

Commanding Officer
SOUTHNAVFACENGCOM
(Code 1846)
2155 Eagle Drive
North Charleston, SC 29419-9010

US NAVY MONITORING INSPECTION FORM FOR WELLS AT HOSPITAL

Activity Name: NAVAL HOSPITAL MILLINGTON

Tank No.'s 106, 107

(1)		(2)		(3)	(4)	(5)		(6)		(7)		(8)	(9)
WELL PURGE		WELL ID NUMBER	PETROLEUM VAPOR PPM	WATER LEVEL		WATER DEPTH		SAMPLE TAKEN		VISUAL INSPECTION OF FREE PRODUCT THICKNESS TO 1/8"	PRINT N		
DATE	TIME			FT	IN	FT	IN	DATE	TIME				
4-29-97	0800	B-1		12	4	15	1	4-30-97	0810	Looks ok. Smells ok	Tom Tera		
4-29-97	0830	B-3		3	2	13	7	4-30-97	0840	Looks ok. Smells ok	Tom Tera		
4-29-97	0900	B-4		2	5	13	2	4-30-97	0910	No freeproduct & odor	Tom Tera		

- NOTES:
1. Wells are as follows: B1-27'5", B2-21'7", B3-22'9", B4-15'7"
 2. Depth measurements should be to the nearest 1/8" or 0.01'.
 3. Inspection equipment must be thoroughly decontaminated between wells.
 4. Evidence of free product shall be reported to PWD Environmental Division

REMARKS: _____

END(3)