

N00639.AR.002306
NSA MID SOUTH
5090.3a

LETTER REGARDING TENNESSEE DEPARTMENT OF ENVIRONMENT AND
CONSERVATION REVIEW AND NOTICE OF DEFICIENCY FOR CORRECTIVE ACTION
PLAN NAVAL HOSPITAL BUILDING H-100 MILLINGTON SUPPACT TN
08/11/1993
TENNESSEE DEPARTMENT OF ENVIRONMENT AND CONSERVATION

FAX TRANSMITTAL

of pages = 2

To John Karlyk	From Tonya Barker
Dept./Agency South Div	Phone # 966-5461
Fax # 563-0465	Fax # 966-5300



NSN 7540-01-317-7288 5099-101 GENERAL SERVICES ADMINISTRATION

STATE OF TENNESSEE
DEPARTMENT OF ENVIRONMENT AND CONSERVATION
MEMPHIS ENVIRONMENTAL FIELD OFFICE
SUITE E-645, PERIMETER PARK
2600 MT. MORIAH
MEMPHIS, TENNESSEE 38115

August 11, 1993

CERTIFIED MAIL P 187 933 343
RETURN RECEIPT REQUESTED

Commanding Officer, NAS Memphis
Code 01010
7800 Third Avenue
Millington, TN 38054-5045

Attention: Mr. Mike Kemp

RE: Notice of Deficiency
CAP
Naval Hospital
Building H-100, Navy Road
UST Facility ID # 0-791707, Shelby County

Dear Mr. Kemp:

The Division of Underground Storage Tanks (the Division) has reviewed the CAP, dated December 11, 1992 for the above referenced facility. The Division has determined the CAP deficient.

The Corrective Action "No Action" chosen to monitor the soil and the groundwater is unacceptable because it doesn't correct the existing problem. Therefore the owner shall propose three Corrective Actions where the chosen action should be the most effective and efficient to fully remediate petroleum contaminated soil and groundwater to the applicable clean-up levels. In accordance with Rule 1200-1-15-.06.

A Revised CAP must be submitted to this office by September 30, 1993.

Send one copy of all correspondence, including reports, to this office and one copy to:

Tennessee Department of Environment and Conservation
Division of Underground Storage Tanks
Fourth Floor, L and C Tower
401 Church Street
Nashville, TN 37243-1541