

N65928.AR.000617  
NTC ORLANDO  
5090.3a

LETTER REGARDING REGULATORY REVIEW AND NO FURTHER ACTION APPROVAL  
FOR OIL WATER SEPARATOR ASSESSMENT AT BUILDING 7184 NTC ORLANDO FL  
4/1/1997  
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

# Department of Environmental Protection

Lawton Chiles  
Governor

Twin Towers Building  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Virginia B. Wetherell  
Secretary

April 1, 1997

Mr. Nick Ugolini  
Code 184(PVC)  
Southern Division  
Naval Facilities Engineering Command  
2155 Eagle Drive  
P.O. Box 190010  
North Charleston, South Carolina 29419-9010


RE: Oil Water Separator Assessment Report Addendum, Building  
7184, Naval Training Center, Orlando, Florida

Dear Mr. Ugolini:

I have completed the technical review of the above referenced addendum dated February 27, 1997 (received March 3, 1997) for the document dated October 25, 1996 (received October 29, 1996). With the resampling analysis indicating no detection of PCE in monitoring well MW-1, I agree that no further action is needed at this site.

If I can be of any further assistance with this matter, please contact me at (904) 921-9989.

Sincerely,



John W. Mitchell  
Remedial Project Manager

cc: Wayne Hansel, Navy SouthDiv  
John Kaiser, ABB Orlando  
Oscar "Mac" McNeil, Bechtel  
Nancy Rodriguez, USEPA Region 4  
Lt. Gary Whipple, NTC Orlando  
Steve McCoy, Brown and Root, Oak Ridge  
Bill Bostwick, FDEP Central District

TJB

JRC

JJC



ESN

ESN

TB