

N61331.AR.001841  
NSA PANAMA CITY  
5090.3a

LETTER REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION  
CONCURRENCE WITH THE TIER II SAMPLING AND ANALYSIS PLAN FOR THE FORMER  
UNDERGROUND STORAGE TANK 2-B, SOIL AND GROUNDWATER INVESTIGATION NSA  
PANAMA CITY FL  
11/16/2011  
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION



# Florida Department of Environmental Protection

Bob Martinez Center  
2600 Blair Stone Road  
Tallahassee, Florida 32399-2400

Rick Scott  
Governor

Jennifer Carroll  
Lt. Governor

Herschel T. Vinyard Jr.  
Secretary

November 16, 2011

Department of the Navy  
Naval Facilities Engineering Command Southeast  
Attn: Mr. John Schoolfield, P.E.  
Ajax Street, Building 135N,  
P.O. Box 30A  
Naval Air Station Jacksonville  
Jacksonville, Florida 32212-0030

**RE: Tier II Sampling and Analysis Plan for the Former Underground Storage Tank 2-B, Soil and Groundwater Investigation, Revision 1, Naval Operations Support Center located in Tallahassee, Naval Support Activity Panama City, USEPA ID# FL8 170 023 792, Facility ID #03-8518667, Panama City Beach, Florida (Engineering Strategies Corporation, October 2011)**

Dear Mr. Schoolfield:

I have reviewed the subject document which is dated October 2011 and was received on October 26, 2011. This Sampling and Analysis Plan (SAP) presents the subsurface soil and groundwater investigation to be conducted at the Naval Operations Reserve Center (NOSC) located in Tallahassee, formerly known as the Tallahassee Naval and Marine Corps Reserve Center.

In the Executive Summary section, the SAP states "*Chlorinated solvents, lead, and methyl tertiary butyl ether (MTBE) were detected in groundwater during the removal of Underground Storage Tank (UST) 2-B. As a result, this site investigation will be completed following the site assessment procedures provided in Florida Administrative Code (F.A.C.) 62-770.*" The report goes on to state "*The major components of the site investigation will be groundwater sampling, subsurface soil sampling, and site-specific hydrogeological characterization.*"

I am in concurrence with the sampling and analysis plan outlined for this soil and groundwater investigation at this site which is contained in this SAP document. I especially want to point out that Worksheet #11, Page 12, contains a concise outline of the activities that are to be performed during this investigation. Worksheet #15 and

Figure 2 (Proposed Monitoring Well and Borehole Locations) are also excellent sources of information pertaining to the sampling activity which is to be conducted. Worksheet #15 contains the COCs for the site in both soil and groundwater, and shows the laboratory methods to be used as well as the contaminants cleanup target level(s) (CTLs). However, it is unclear to me if this is the Draft-Final or Final Document. If this is the Draft-Final document then please send me, at your earliest convenience, the Final version so that I may concur with it. Also, please send me the signature page so I may sign it. Finally, at the end of this initial site assessment it will be determined, based on the analytical data, which of Department's Rules, 62-780 or 62-770, the site will be governed by.

Thank you for the opportunity to review this document. If you require additional clarification or other assistance, please feel free to contact me at 850/245-8999.

Sincerely,



John Winters, P.G.  
Remedial Project Manager

KAW 

ESN 

Cc Tim Bahr, FDEP, Tallahassee