

N00204.AR.004165
NAS PENSACOLA
5090.3a

LETTER REGARDING REGULATORY REVIEW AND CONDITIONAL CONCURRENCE ON
FIRST QUARTER YEAR 2 GROUNDWATER MONITORING LETTER REPORT FOR
UNDERGROUND STORAGE TANK 17 NAS PENSACOLA FL
7/1/2002
FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION

CTO 223



Department of Environmental Protection

Jeb Bush
Governor

Twin Towers Building
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

David B. Struhs
Secretary

July 1, 2002


Mr. Byas Glover
Code 18410
Southern Division
Naval Facilities Engineering Command
2155 Eagle Drive
P.O. Box 190010
North Charleston, South Carolina 29419-9010

RE: The First Quarter (Year 2) Groundwater Monitoring
Letter Report for Site 17, NAS Pensacola, DEP Facility
#179202973

Dear Mr. Glover:

I have completed the technical review of the above referenced document dated May 28, 2002, (received May 28, 2002). The document is adequate for its intent. I propose that you resample MW-9 using the low flow sampling technique during the next sampling event. I agree with the recommendation to continue quarterly monitoring at the site.

If I can be of any further assistance with this matter, please contact me at (850) 921-9988.



Sincerely,

Tracie Vaught
Remedial Project Manager

cc: Greg Campbell, NAS Pensacola
~~Greg Campbell~~ Tetra Tech NUS, Tallahassee
Charlie Goddard, FDEP Northwest District

TJB B

JJC me

for
ESN me

"Protect, Conserve and Manage Florida's Environment and Natural Resources"

Printed on recycled paper.