

N00204.AR.004757
NAS PENSACOLA
5090.3a

NOVEMBER 1997 MONTHLY OPERATION AND MAINTENANCE REPORT ON THE
DOMESTIC WASTEWATER TREATMENT PLANT GROUNDWATER REMEDIATION
PROJECT FOR NAS PENSACOLA FL
12/3/1997
HRP SPECTRUM INC

December 3, 1997

Southern Division
NAVFACENGCOM
Attention: Maxie Keisler, Code 18213
2155 Eagle Drive
P.O. Box 190010
Charleston, SC 29419-9010

RE: NOVEMBER, 1997 MONTHLY OPERATION AND MAINTENANCE REPORT ON THE DOMESTIC WASTEWATER TREATMENT PLANT (DWTP) GROUND-WATER REMEDIATION; NAVAL AIR STATION (NAS) PENSACOLA, FLORIDA, (JOB # NAV0303.FE)

Dear Sir:

HRP/Spectrum is pleased to submit the November 1997 monthly report for the operation and maintenance activities conducted on the DWTP Ground Water Treatment System for the above referenced project. The attached Table 1 contains a summary of the recovery well pumping data for the month of November 1997 and Attachment "A" contains time series graphs of the calculated bi-weekly pump flow rates and measured well water levels to facilitate evaluation of the performance and maintenance requirements of the recovery wells and pumps. In addition, four (4) copies of the report have been sent to Mr. Tom Kelley, Naval Public Works Center and two (2) copies to Commander, Naval Air Station, Environmental Division, Attention: Mr. Bill Taylor. *HRP/Spectrum* has the following comments for the month of November:

RECOVERY WELL SYSTEM OPERATION STATUS

RW 1,2&3

- On November 10, 1997 RW's 1,2, & 3 were in operation. The pumps and wells appeared to be in good condition producing normal pressure and flow. No leaks were observed.
- On November 24, 1997 Pump B for RW's 1,2, & 3 were in operation. The pumps and well appeared to be in good condition producing normal pressure and flow. No leaks were observed or detected.

RW 4&6

- On November 10, 1997 Pump A for RW 4 & 6 was operating sufficiently with normal pressure and flow. No leaks were detected at either of the recovery wells or pumps.
- After performing RW rehabilitation during the last week of October on RW 4 & 6, there was a twelve (12%) percent decrease in flow noted for RW 4 & 6 during the month of November. The reason for the decrease in flow was that a new water supply pump was installed on RW 5A in October, and RW 4 & 6 could not supply enough pressure to maintain past flow rates.
- On November 24, 1997 RW 4 & 6 was not in operation upon arrival. The local breaker switch had been turned off by local WWTP employees. The recovery well was restarted, allowed to prime, and well data was recorded. Upon departure, no leaks were detected at either of the recovery wells or pumps.

RW 5A

- On November 10, 1997 Pump B of RW 5A was operating sufficiently with normal pressure and flow. No leaks were detected at either the recovery well or pumps.
- After performing RW rehabilitation during the last week of October on RW 5A, there was a twenty-four (24%) percent increase in flow from the month of November.
- On November 24, 1997, RW 5A was not in operation upon arrival. The local breaker switch had been turned off by local WWTP employees. The recovery well was restarted, allowed to prime, and well data was recorded. Upon departure, no leaks were detected at either the recovery well or pumps.

RW 7

- On November 10, 1997 Pump A appeared to be working properly producing normal pressure and flow. No leaks were detected in either the pumps or well.
- On November 24, 1997 Pump A appeared to be working properly producing normal pressure and flow. No leaks were detected in either the pumps or well.


PRE-TREATMENT AIR STRIPPER

- On November 10, 1997 the Air Stripper was operating properly. No leaks were detected.
- On November 24, 1997 the Air Stripper was operating properly. No leaks were detected.

If you have any questions regarding this report or other matters pertaining to this project, please contact me at (864) 298-0231.

Sincerely,

HRP/Spectrum



Anthony L. Gentry
Project Engineer

ALG/cmc

Enclosure

cc: Tom Kelley-Naval Public Work Center- Code 480 (4 copies)
Bill Taylor - NAS Pensacola - Code 00500 (2 copies)

Attachment #1

Time Series Graph

TABLE 1
NAS PENSACOLA
RECOVERY WELL PUMPING DATA

PUMP STATION	DATE INSPECTED	TIME (MILITARY)	FLOW METER READING (GALLONS)	DISCHARGE PRESSURE (psig)	SUCTION VACUUM ("Hg)	INSTANTANEOUS PUMPING FLOW RATE (GPM)	CALCULATED BI-WEEKLY FLOW RATE (GPM)	PUMP IN USE (A or B)	ELAPSED TIME (HOURS)	TOTAL BI-WEEKLY FLOW (GALLONS)	WATER LEVEL BELOW TOP OF CASING (Ft) (RESPECTIVELY)
RW 1,2 & 3	11/10/97	10:05	13,408,890	15	16.5	7	6.08	B	336	122,530	N/A, N/A, 4.79
RW 4&6	11/10/97	10:15	4,570,290	5	12	4.5	3.74	A	336	75,330	2.94, 5.16
RW 5A	11/10/97	10:20	7,530,390	47	10	13.5	11.91	B	336	240,020	5.18
RW 7	11/10/97	10:30	6,675,590	9	21.5	2.4	2.13	A	336	42,840	23.22
RW 1,2 & 3	11/24/97	10:40	13,552,480	8	16.5	7.1	7.12	B	336	143,590	N/A, N/A, 4.56
RW 4&6	11/24/97	10:50	4,639,600	5	12.5	4.6	3.44	A	336	69,310	2.65, 4.85
RW 5A	11/24/97	11:00	7,725,790	46	12.5	9.6	9.69	B	336	195,400	5.36
RW 7	11/24/97	11:07	6,725,520	8	22.5	2.4	2.48	A	336	49,930	23.24

NOTES:

RW 1,2 3 - Recovery station for recovery wells RW 1, RW 2, and RW 3.

RW 4 6 - Recovery well for wells RW 4 and RW 6.

INSPECTOR'S NAME	ANTHONY L. GENTRY
DATE	11/10/97
AMBIENT TEMPERATURE	62
WEATHER CONDITIONS	CLOUDY

ITEM	INSPECTION CHECK	INSPECTION FREQUENCY	DATA/ COMMENTS
INFLUENT PIPING	OPERATION OF BALL CHECK VALVE	MONTHLY	OK
	SAMPLE PORT OPERATION	MONTHLY	OK
	FLOW METER READING	BI-WEEKLY	13,157,560
	SAMPLE COLLECTION	MONTHLY	N/A
AIR STRIPPER	PRESSURE GAUGE READING	BI-WEEKLY	20.0" WATER
	CLEAN / CHECK TRAYS	BI-WEEKLY	CHECKED
BLOWER	PIPING CONNECTIONS	MONTHLY	OK
EFFLUENT PIPING	OPERATION OF BALL CHECK VALVE	MONTHLY	OK
	SAMPLE PORT OPERATION	MONTHLY	OK
	FLOW METER READING	BI-WEEKLY	N/A
	SAMPLE COLLECTION	MONTHLY	N/A
SYSTEM COMPONENTS	EXPOSED PIPING CONNECTIONS	MONTHLY	OK

SYSTEM DESCRIPTION:

ACTIVITIES PERFORMED:

INSPECTOR'S NAME	ANTHONY L. GENTRY
DATE	11/24/97
AMBIENT TEMPERATURE	72
WEATHER CONDITIONS	PARTLY SUNNY

ITEM	INSPECTION CHECK	INSPECTION FREQUENCY	DATA/ COMMENTS
INFLUENT PIPING	OPERATION OF BALL CHECK VALVE	MONTHLY	OK
	SAMPLE PORT OPERATION	MONTHLY	OK
	FLOW METER READING	BI-WEEKLY	13,501,990
	SAMPLE COLLECTION	MONTHLY	N/A
AIR STRIPPER	PRESSURE GAUGE READING	BI-WEEKLY	19.5" WATER
	CLEAN / CHECK TRAYS	BI-WEEKLY	CHECKED
BLOWER	PIPING CONNECTIONS	MONTHLY	OK
EFFLUENT PIPING	OPERATION OF BALL CHECK VALVE	MONTHLY	OK
	SAMPLE PORT OPERATION	MONTHLY	OK
	FLOW METER READING	BI-WEEKLY	N/A
	SAMPLE COLLECTION	MONTHLY	N/A
SYSTEM COMPONENTS	EXPOSED PIPING CONNECTIONS	MONTHLY	OK

SYSTEM DESCRIPTION:

ACTIVITIES PERFORMED:

**ATTACHMENT 1
GROUNDWATER FLOW READINGS**

DATE	RW 1,2,&3	RW 4&6	RW 5A	RW 7	TOTAL
1/3/95	124,006	141,588	2,629	36,814	305,037
1/17/95	121,155	141,168	103,562	37,668	403,553
1/31/95	20,528	143,045	160,533	7,741	331,847
2/14/95	118,171	139,268	33,440	39,172	330,051
2/28/95	112,145	124,628	195,889	37,053	469,715
3/14/95	123,141	194,925	190,593	45,607	554,266
3/28/95	125,571	152,781	147,296	46,200	471,848
4/11/95	121,568	184,651	2,015	45,893	354,127
4/25/95	126,623	147,850	224,282	47,128	545,883
5/9/95	94,185	167,684	220,647	46,206	528,722
5/23/95	80,867	135,931	100,613	46,105	363,516
6/6/95	136,660	157,320	332,514	44,446	670,940
6/20/95	94,863	132,718	78,605	42,396	348,582
7/4/95	122,115	150,562	1,577	40,923	315,177
7/18/95	128,917	131,634	148,926	41,204	450,681
8/1/95	134,318	152,703	132,928	41,322	461,271
8/10/95	94,856	88,538	87,222	29,445	300,061
8/22/95	122,086	134,403	123,028	37,154	416,671
9/5/95	131,628	133,923	120,794	43,401	429,746
9/19/95	137,823	155,558	93,131	43,165	429,677
10/3/95	129,645	132,519	50,273	40,028	352,465
10/25/95	12,024	136,159	69,476	3,701	221,360
11/8/95	22,566	82,653	78,603	0	183,822
11/21/95	15,068	20,731	13,571	45,233	94,603
5/31/96	9,722	10,033	2,577	4,760	27,092
6/6/96	59,060	42,822	439	22,325	124,646
6/12/96	56,952	49,788	460	21,626	128,826
6/19/96	59,513	80,468	1,555	26,465	168,001
6/26/96	56,512	86,242	0	28,001	170,755
7/11/96	6,264	123,432	-3,289	59,241	185,648
8/8/96	80,000	120,000	0	60,000	260,000
8/21/96	153,290	90,540	0	55,670	299,500
9/4/96	0	154,470	49,184	60,980	264,634
9/23/96	192,330	0	220,336	82,000	494,666
10/9/96	0	188,940	164,420	57,760	411,120
10/28/96	191,710	220,050	0	79,580	491,340
11/19/96		266,730	10,080	70,950	347,760
12/3/96	0	184,490	262,710	47,130	494,330
12/16/96	125,560	158,840	242,580	44,410	571,390
1/6/97	211,440	225,360	391,290	69,570	897,660
1/28/97	203,820	286,830	130,110	72,700	693,460
2/11/97	140,470	194,330	95,910	49,490	480,200
3/14/97	313,290	437,710	191,710	101,070	1,043,780
3/25/97	110,100	147,810	65,650	34,540	358,100
4/16/97	169,240	215,640	102,140	55,370	542,390
4/29/97	109,650	98,960	32,710	38,680	280,000
5/16/97	161,300	105,890	204,190	56,590	527,970
5/29/97	129,190	83,640	156,490	43,120	412,440
6/10/97	192,010	123,890	209,690	83,390	416,970

**ATTACHMENT 1
GROUNDWATER FLOW READINGS**

DATE	RW 1,2,&3	RW 4&6	RW 5A	RW 7	TOTAL
6/26/97	65,640	41,840	56,390	0	163,870
7/14/97	167,630	109,340	109,800	0	386,770
8/5/97	290	123,010	0	72,580	195,880
8/19/97	141,650	86,850	28,060	54,660	311,220
9/3/97	150,690	92,500	176	56,910	300,276
9/17/97	140,450	85,610	0	51,390	277,450
10/6/97	193,180	118,120	0	68,230	379,530
10/27/97	210,410	127,460	275,934	70,980	684,784
11/10/97	122,530	75,330	240,020	42,840	480,720
11/24/97	143,590	69,310	195,400	49,930	458,230

NOTE: Large peak on 3/14/97 is due to no second site visit during the month of February.

Attachment #1
Time Series Graph

PUMPING FLOW (GALLONS SINCE LAST READING)

NAS PENSACOLA
GROUNDWATER RECOVERY WELL FLOW RATES

