



DEPARTMENT OF THE NAVY

U S NAVAL STATION ROOSEVELT ROADS

PSC 1008 BOX 3001

FPO AA 34051-3001

5090

Ser N46E4/1242

2 Dec 03

U.S. Environmental Protection Agency - Region 2
RCRA Program Branch
290 Broadway - 22nd Floor
New York, NY 1007-1866

Attention: Mr. Tim Gordon

SUBJECT: COLLAPSED SEWAGE LINE AT SOLID WASTE MANAGEMENT UNIT #45

As discussed during the telephone conversation between you and Mrs. Madeline Rivera and Mr. Pedro Ruiz of my staff on November 20, 2003, we want to inform you of the corrective action plan for repairing the sewer line that collapsed on November 19, 2003 impacting an area of Solid Waste Management Unit (SWMU) #45. The enclosed drawing provides the approximate location of the impacted area.

Our plan of action includes the following:

- a. Bypass the system flow from the upstream manhole to the low stream manhole so the area can be secured for the repairs.
- b. Prepare the surface area where the new piping will be installed. This may include excavation of soil from the impacted SWMU.
- c. Any soil excavated from the impacted SWMU will be placed in a temporary berm for disposal.
- d. Install the new piping and backfill.
- e. Dispose the excavated soil based on test results.

Additional information on test results and any required soil disposal will be included in the Resource Conservation and Recovery Act (RCRA) Quarterly Reports required under the Station RCRA Permit.

5090
Ser N46E4/

Should you have any questions, please contact Mrs. Madeline Rivera or Mr. Pedro Ruiz, Environmental Engineers, Environmental Engineering Division, Public Works Department, at (787) 865-4152 extensions 460/459 respectively.

Sincerely,



S. R. LISTER
Commander, CEC, U.S. Navy
Public Works Officer
By direction of the
Commanding Officer

Enclosure

Copy to: (w/o enclosure)
Commander
Atlantic Division (EV21)
Naval Facilities Engineering Command
6505 Hampton Blvd.
Norfolk, VA 23508-1278

Mr. Mark Kimes
Michael Baker Inc.
Airside Business Park
100 Airside Drive
Moon Township, PA 15108