

N60508.AR.000495
NAS WHITING FIELD
5090.3a

LETTER REGARDING FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION
OBSERVATIONS ON FINISHED WATER SUPPLY EXCEEDING TRICHLOROETHENE
DRINKING WATER STANDARD NAS WHITING FIELD FL
2/17/1986
FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

STATE OF FLORIDA
DEPARTMENT OF ENVIRONMENTAL REGULATION

18.01.00.0017

00760

11102 DC 7/29
11411 mg

11429 mg
BOB GRAHAM
GOVERNOR
VICTORIA J. TSCHINKEL
SECRETARY

ROBERT V. KRIEGLER
DISTRICT MANAGER



FEB 17 1986

NAS Whiting Fld. /
File 7

NORTHWEST DISTRICT

160 GOVERNMENTAL CENTER
PENSACOLA, FLORIDA 32501-5794

Mr. D. R. Spell, P.E.
Head Environmental Branch
Department of the Navy
Southern Division
Naval Facilities Engineering Command
2144 Melbourne Street
P.O. Box 10068
Charleston, South Carolina 29411

Dear Mr. Spell:

This is in response to your letter of January 28, 1986 regarding NAS Whiting Field finished water supply exceeding the drinking water standard for Trichloroethylene (TCE).

Some observations regarding the sampling are:

- a. The TCE was found at ATS. Rechecks were then taken at AT52 and AT52.
- b. Benzene was found exceeding the MCL when doing rechecks at AT52.
- c. No information was provided indicating that blanks were run at the lab for TCE and Benzene.


It is recommended that:

- a. The rechecks for TCE be done at ATS.
- b. Rechecks be accomplished for Benzene at AT52.
- c. The lab run blanks for TCE and Benzene.

It is noted that a complete priority pollutants analysis is not required for all the volatiles when doing rechecks.

If you have any questions, please do not hesitate to call me at
(904) 436-8380.

Sincerely,



J. A. Kintz, P.E.
Potable Water Engineer

JAK/jks

cc: CDR R.A. Kechter, CEC, USN, - NAS Whiting Field
Mike Webb - DER Tallahassee with a copy of Mr. Spell's
letter of January 28, 1986