

N60508.AR.000500
NAS WHITING FIELD
5090.3a


LETTER RECOMMENDING ADDITIONAL WATER SAMPLES BE TAKEN AT THE POTABLE
WATER WELLS NAS WHITING FIELD FL
8/28/1986
FLORIDA DEPARTMENT OF ENVIRONMENTAL REGULATION

00763

STATE OF FLORIDA

DEPARTMENT OF ENVIRONMENTAL

NORTHWEST DISTRICT

160 GOVERNMENTAL CENTER
PENSACOLA, FLORIDA 32501-5794

August 28, 1986

Please check with some station re action Advise me

BOB GRAHAM
GOVERNOR

VICTORIA J. TSCHINKEL
SECRETARY

ROBERT V. KRIEGL
DISTRICT MANAGER

1433 ^{cc}
will do

*File 11
NAS Whiting*

R. A. Kechter
Commander, CEC, USN
Public Works Officer
Naval Air Station, Whiting Field
Milton, Florida 32570

Dear Commander Kechter:


This is in response to the letter from Glenn Bradley of Southern Division, Naval Facilities Engineering Command of August 19, regarding groundwater monitoring at the battery shop and included sampling and analysis of the South potable water well (#W-S2). It is also a follow up to our telephone conversation August 28.

As discussed in our telephone conversation, it is recommended that additional sampling and analysis be done in view of the fact that three out of four monthly results for benzene exceeded the maximum contaminant level (MCL) in Florida Administrative Code Rule 17-22.104(1)(g) in well #W-S2. It is requested that you sample each of your potable water wells and take two samples from the distribution system (representative, after blending) for the Volatile Organics in Rule 17-22.104(1)(g). It is requested that this sampling and analysis be accomplished as soon as possible.

It is also requested that well #W-S2 immediately be taken out of service. It shall remain out of service until it can be demonstrated all parameters are below the standards in Rule 17-22.104 and/or appropriate treatment is provided.

If you have any questions on the above, please do not hesitate to call me at (904)436-8380.

Sincerely,

A handwritten signature in cursive script, appearing to read "J. A. Kintz".

J. A. Kintz, P.E.
Potable Water Engineer

JAK/jks
DGS475

cc: Glenn Bradley
Mike Webb, DER Tallahassee (W/copy of Glenn Bradley letter
of Aug 19, 1986