

TECHNICAL REVIEW COMMITTEE
MEETING AGENDA
MCAS EL TORO

OCTOBER 26, 1990

| <u>ITEM</u> | <u>PRESENTOR</u> |
|---|--------------------|
| I. INTRODUCTION | MCAS EL TORO |
| II. BACKGROUND ON FEDERAL FACILITIES AGREEMENT | SOUTHWEST DIVISION |
| III. STATUS OF MCAS EL TORO TCE TREATMENT PLANT | MCAS EL TORO |
| IV. STATUS OF OCWD PUMP-OUT PROJECT | OCWD |
| V. COMMUNITY RELATIONS PLAN PRESENTATION | CH2M HILL |
| VI. RI/FS WORKPLAN PRESENTATION | CH2M HILL |
| VII. QUESTION AND ANSWER SESSION | _____ |

ON-BASE TCE MONITORING/TREATMENT PLANT UPDATE

- 13 MONTHLY MONITORING PROGRAMS REPORT COMPLETED STARTING JUL 89
- NEW CONTRACT BEING DEVELOPED TO EXTEND TREATMENT UNTIL AT LEAST SEP 91
- JMM IS CURRENT CONTRACTOR
- 3.3 MILLION GALLONS TREATED TO DATE
- UNIT 1 GAC TANK REPLACED FEB 90 DUE TO BREAKTHROUGH (5.8 ppb) OF CIS 1, 2 - DICHLOROETHYLENE. LATEST SAMPLING SHOWED BREAKTHROUGH (3 ppb) OF CIS 1,2 - DICHLOROETHYLENE