

DEPARTMENT OF HEALTH SERVICES
TOXIC SUBSTANCES CONTROL PROGRAM
2151 BERKELEY WAY, ANNEX 9
BERKELEY, CA 94704
(415) 540-3816



December 7, 1990

Commanding Officer
Naval Station Treasure Island
Building I (Code 84)
San Francisco, CA 94130-5000
Attn: Eddie Sarmiento

Dear Mr. Sarmiento:

DHS COMMENTS ON THE DRAFT ASBESTOS ABATEMENT ADDENDUM TO THE
REMOVAL ACTION WORKPLAN FOR THE TANK FARM - HUNTERS POINT ANNEX

Enclosed are the Department of Health Services (Department)
comments on the above referenced draft workplan. The Department
did not receive comments from the Bay Area Air Quality Management
District or Regional Water Quality Control Board.

The Department has reviewed and concurs with comments previously
submitted by the EPA. Please respond to all comments on a point-
by-point basis and add comments and responses as an appendix to the
final draft work plan.

If you have any questions regarding these comments, please contact
me at (415) 540-3816.

Sincerely,

A handwritten signature in cursive script that reads "Mark Malinowski".

Mark Malinowski
Engineering Geologist
Region 2
Toxic Substances Control Program

Enclosure(s)

cc: See Attached List

1707
D/N 84

Mr. Sarmiento
Page 2
December 7, 1990

Julie Carver
Western Division
Naval Facilities Engineering
P.O. Box 727
San Bruno, CA 94066-0720

Louise Lew
Western Division
Naval Facilities Engineering
P.O. Box 727
San Bruno, CA 94066-0720

Chuck Flippo, (H-7-5)
U.S. EPA, Region IX
75 Hawthorne Street
San Francisco, CA 94105

Tom Gandesbery
S.F. Bay, RWQCB
1800 Harrison Street., Ste. 700
Oakland, CA 94612

Scott Lutz
BAAQMD
939 Ellis Street
San Francisco, CA 94109

Comments on the
Draft Addendum Removal Action Work Plan
Asbestos Abatement, Tank Farm - Hunters Point Annex

Specific Comments

<u>Pg</u>	<u>Sec.</u>	<u>Pgph.</u>	<u>Comment</u>
10	2.3		Add PCM to the definition list.
18	4.5	1	The technical plan should specify the location of the asbestos waste storage area.
24	6.0	1	Line 6. "... results will be available within 24 hours <u>except as noted below.</u> " Since no exceptions to the 24 hour turn around are noted, please remove the "except as noted below" qualifier.
24	6.1		Specify if the three samples will be collected at a single station at different times of the day or if three stations will be sampled at a single time. Specify the type of sampler to be used.
24	6.2		Specify the type of sampler to be used for monitoring worker exposure. The sampler and sampling methods must meet Federal regulatory standards.
24	6.2		Specify the types of corrective measures that may be taken to correct high airborne fiber concentrations.